

Date: 6 January 2025
Application: 243194



**WOKINGHAM
BOROUGH COUNCIL**

SDL Flood Risk Officer

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear SDL Flood Risk Officer,

Variation/Removal of Condition Consultation

Application Number: 243194

Applicant: Antler Homes

Site Address: Land to the West of St Annes Drive and South of London Road, Wokingham, RG40 1PB

Parish: Wokingham Town

Grid Reference: Easting - 483345, Northing - 168621

Type of Development: Major Dwellings (10+)

Proposal: Application to vary condition 2 of planning consent 203544 (approved under APP/X0360/W/22/3297645) for the proposed erection of 54 units (including 19 affordable homes) with associated access road from St Anne's Drive, landscaping and open space. Condition 2 refers to the approved details and the variation is to amend the drawings to include the addition of single storey rear extensions to approved plots 2, 3, 4, 7, 50, 51 and 52.

Case Officer: Joanna Carter

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 243194. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,

Development Management & Compliance

MEMORANDUM

From:	Boniface Ngu Flood Risk & Drainage		
Service	SDL Flood Risk Officer	App No:	243194
Address:	Land to the West of St Annes Drive and South of London Road, Wokingham, RG40 1PB.		
Proposal:	Application to vary condition 2 of planning consent 203544 (approved under APP/X0360/W/22/3297645) for the proposed erection of 54 units (including 19 affordable homes) with associated access road from St Anne's Drive, landscaping and open space. Condition 2 refers to the approved details and the variation is to amend the drawings to include the addition of single storey rear extensions to approved plots 2, 3, 4, 7, 50, 51 and 52.		
Type of Development:	Major Dwellings (10+)		
Site Visit Made:	No		

Summary Of Recommendations

- ☐ No comment
- ☐ No objection
- ☐ No objection subject to conditions (and reasons) **stated below**
- ☒ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

Process Planning cover letter dated 18/12/2024 states that the proposal is to add single storey rear extensions to Plots 2, 3, 4, 7, 50, 51 and 52.

We note that the letter considers the extensions to be minor but as the impermeable area increases, we would like to understand how this impacts on the drainage strategy.

Please provide revised calculations accommodating the extra impermeable areas created, demonstrating that runoff is adequately managed on site.

Conditions & Reasons (if required)

Please use this section to detail any conditions that are required to make this development acceptable in planning terms. All conditions should be accompanied by reasons.

Date:	06/01/2025	Signed:	Boniface Ngu
--------------	------------	----------------	--------------

