

Date: 11 October 2024
Application: 242290



**WOKINGHAM
BOROUGH COUNCIL**

WBC Highways

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Highways,

Householder Consultation

Application Number: 242290

Applicant: Mr and Mrs P and A Gambhir

Site Address: 85 Elm Road, Earley, Wokingham, RG6 5TB

Parish: Earley

Grid Reference: Easting - 473761, Northing - 170950

Type of Development: Other Householder

Proposal: Householder application for the proposed erection single storey side extension with skylights following the demolition of the existing garage.

Case Officer: Rowan Reynolds

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 242290. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	AC		
Service	WBC Highways	App No:	242290
Address:	85 Elm Road, Earley, Wokingham, RG6 5TB.		
Proposal:	Householder application for the proposed erection single storey side extension with skylights following the demolition of the existing garage.		
Type of Development:	Other Householder		
Site Visit Made:	Yes/No		

Summary Of Recommendations

- ☐ No comment
- ☒ No objection
- ☐ No objection subject to conditions (and reasons) **stated below**
- ☐ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

The proposal will result in an additional habitable room, however, this will not have a significant impact in respect of the councils parking standards.

The garage is to be removed. The existing level of driveway parking will be retained and this is considered acceptable to serve the development.

Date:	15/10/24	Signed:	AC
--------------	----------	----------------	----