

Date: 19 December 2024
Application: 242967



**WOKINGHAM
BOROUGH COUNCIL**

WBC Drainage

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Drainage,

Full Planning Approval Consultation

Application Number: 242967

Applicant: Wokingham Theatre

Site Address: Wokingham Theatre, Twyford Road, Wokingham, RG40 5TU

Parish: Wokingham Town

Grid Reference: Easting - 480772, Northing - 169738

Type of Development: Minor All other developments

Proposal: Full application for the proposed erection of a two-storey extension to form a studio block, plus the erection of a link between the main building and the storage barn (which is to be retained on a permanent basis); closure of the old access and creation of public parking spaces, formation of a new access and installation of hardstanding to form on-site parking.

Case Officer: Tariq Bailey-Biggs

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 242967. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	Boniface Ngu Flood Risk & Drainage		
Service	WBC Drainage	App No:	242967
Address:	Wokingham Theatre, Twyford Road, Wokingham, RG40 5TU.		
Proposal:	Full application for the proposed erection of a two storey extension to form a studio block, plus the erection of a link between the main building and the storage barn (which is to be retained on a permanent basis); closure of the old access and creation of public parking spaces, formation of a new access and installation of hardstanding to form on-site parking.		
Type of Development:	Minor All other developments		
Site Visit Made:	No		

Summary Of Recommendations

- ☐ No comment
- ☐ No objection
- ☒ No objection subject to conditions (and reasons) **stated below**
- ☐ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

The site is within flood zone 1 and we would have no objection to the principle of the development as represented by **proposed elevations drawings 142/203 C and 142/104 A, both dated December 2023.**

Proposed Phase and location plan drawing 142/206 B indicates an eastern extension and thus an increased footprint of the building.

The **application form** proposes managing surface water runoff via soakaway while foul water will connect into an existing foul sewer network.

Based on the above, with drainage details not provided, we would **recommend the condition below:**

Conditions & Reasons (if required)

No development shall take place until full details of the drainage system for the site have been submitted to and approved in writing by the LPA. The details shall include:

1. BRE 365 test results demonstrating that infiltration is achievable.
2. Full calculations demonstrating the performance of soakaways.

3. Groundwater data confirming seasonal high groundwater levels in the area.
4. A drainage strategy plan indicating the location and sizing of SuDS features, with the base of any SuDS features located at least 1m above the seasonal high water table level.
5. Details demonstrating how any SuDS for this development would be managed throughout the lifespan of the development and who will be responsible for maintenance.

This is to prevent increased flood risk from surface water run-off. Relevant policy: NPPF Section 14 (Meeting the Challenge of Climate Change, Flooding and Coastal Change), Core Strategy policy CP1 and Managing Development Delivery Local Plan policies CC09 and CC10.

Date:	20/12/2024	Signed:	Boniface Ngu
--------------	------------	----------------	--------------