

251385 DOCO Response

Dear Sir or Madam,

Thank you for consulting Thames Valley Police in relation to the revised information submission for the above application. I have reviewed the submitted information and note that the site plan now includes further detail regarding the proposed Paladin security fencing and gates proposed around the proposed masts and yard. It is noted that the gate details indicate they will be flat topped and with large openings around the locking mechanism which could provide a climbing aid. This has the potential to undermine the security provided by the 2.4m paladin fencing. Both the fencing and the gate should be anti-climb and the gate must be sufficiently robust so that when locked it cannot be pushed or pulled to create gaps.

The above comments are made on behalf of Thames Valley Police and relate to designing out crime only. I hope that you find these comments of assistance. If you have any queries relating to crime prevention design, please do not hesitate to contact me.

Regards

Dan

Daniel Washington

Designing Out Crime Officer

Community Policing