

**East Hub Fire Safety Office, Maidenhead Fire Station, Bridge Road,
Maidenhead, Berkshire, SL6 8PG
Email: easthubfiresafety@rbfrs.co.uk
Direct Line 07586566500 Switchboard 0118 945 2888
Royal Berkshire Fire and Rescue Service  rbfrs.co.uk**



Sent via email:
planning.enquiries@wokingham.gov.uk

Your ref	260798
Our ref	BS/ 37261
Ask for	Beth Smith
Date	02 June 2026

Dear Sir/Madam

Re: Sonning Cutting Filling Station 709 London Road Woodley Wokingham RG6 1BG

Further to your letter dated 13 May 2026 and enclosed plan/s which you have forwarded, it is noted that this application has been made under the Town and Country Planning Acts.

At this stage there is no duty placed upon the Fire Authority under the aforementioned legislation to make any comment relative to your application.

Your proposals have, however, been cursorily examined and inasmuch as would affect the planning application and the following items, in general, will need to be incorporated in order to meet the basic principles of means of escape in case of fire.

Fire service access should comply with B5 of ADB Volume 1 2019a and additional local requirements below under the Berkshire Act 1986:

Fire service vehicles currently operated by Royal Berkshire Fire & Rescue Service exceed the requirements stated in the current edition of Approved Document B.

The applicant should be made aware of the following amendments:

The minimum carrying capacity for a pumping appliance is 16 tonnes.

The minimum carrying capacity for a high reach appliance is 26 tonnes.

Any structural fire precautions and all means of escape provision will have to satisfy Building Regulation requirement. These matters are administered by the local authority Building Control or approved inspectors, who you are advised to contact in this regard.

Chief Fire Officer – Mark Arkwell

Please be advised that any comments made by the Fire Authority in this letter must not be taken as formal approval that your plan/s confirm to the requirements and recommendations of current Guides or Codes of Practice for means of escape in case of fire.

Yours faithfully



Bethany Smith
Authorised Fire Safety Inspector
And on behalf of the Royal Berkshire Fire Authority

Chief Fire Officer – Mark Arkwell