

Wokingham District Council, P.O Box 157, , WOKINGHAM, Berks, RG40 1WR

19 March 2026

Our DTS Ref: 80684

Your Ref: 260600

Dear Sir/Madam,

Re: 6 , KING STREET LANE, WINNERSH, WOKINGHAM, RG41 5SF

Waste Comments:

Waste Comments:With regard to SURFACE WATER drainage, Thames Water would advise that if the developer follows the sequential approach to the disposal of surface water we would have no objection. Management of surface water from new developments should follow guidance under sections 167, 168 & 169 in the National Planning Policy Framework. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. Should you require further information please refer to our website.

<https://www.thameswater.co.uk/help/home-improvements/how-to-connect-to-a-sewer/sewer-connection-design>

Thames Water would advise that with regard to WASTE WATER NETWORK and SEWAGE TREATMENT WORKS infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

Water Comments:

Water Comments:If you are planning on using mains water for construction purposes, it's important you let Thames Water know before you start using it, to avoid potential fines for improper usage. More information and how to apply can be found online at [thameswater.co.uk/buildingwater](https://www.thameswater.co.uk/buildingwater).

On the basis of information provided, Thames Water would advise that with regard to water network and water treatment infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommends the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Supplementary Comments:

Yours faithfully,
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,

Denham Way,
Rickmansworth,
WD3 9SQ,
Email: devcon.team@thameswater.co.uk