

3rd Party Planning Application - 250517 - New Drainage Info

Wokingham District Council, P.O Box 157, , WOKINGHAM, Berks, RG40 1WR

10 July 2025

Our DTS Ref: 76455

Your Ref: 250517 - New Drainage Info

Dear Sir/Madam,

Re: LAND OFF, BASINGSTOKE ROAD, SPENCERS WOOD, BASINGSTOKE, BERKSHIRE, RG7

Waste Comments:

Waste Comments:Thames Water has identified that the existing FOUL WATER network does not have sufficient capacity to support the proposed development. As such, we request that the following condition be attached to any planning permission granted:

The development shall not be occupied until confirmation is provided that either:

1. All necessary upgrades to the foul water network to accommodate additional flows from the development have been completed; or
2. A phasing plan for development and infrastructure, agreed with Thames Water and the Local Planning Authority, is in place. Where such a plan exists, no occupation shall occur other than in accordance with the approved phasing schedule.

Reason: Network reinforcement is likely to be required to support the proposed development. These upgrades are essential to avoid the risk of sewer flooding and pollution incidents.

If the Local Planning Authority considers this condition inappropriate or is unable to include it in the decision notice, it is essential to consult with Thames Water's Development Planning Department at Devcon.team@thameswater.co.uk before determining the application.

Please note where network modelling is required, Thames Water will need confirmation of outline planning permission, a development phasing plan, and evidence of land ownership to be submitted to devcon.team@thameswater.co.uk . Modelling can take 9-12 months to complete and will not commence until these have been provided.

Public sewers are crossing or close to your development. Build over agreements are required for any building works within 3 metres of a public sewer and, or within 1 metre of a public lateral drain. This is to prevent damage to the sewer network and ensures we have suitable and safe access to carry out maintenance and repairs. Please refer to our guide on working near or diverting our pipes:<https://www.thameswater.co.uk/developers/larger-scale-developments/planning-your-development/working-near-our-pipes> Please ensure to apply to determine if a build over agreement will be granted.

Thames Water would advise that with regard to the SURFACE WATER network capacity, we would not

have any objection to the above planning application, based on the information provided.

We would expect the developer to demonstrate what measures will be undertaken to minimise groundwater discharges into the public sewer. Groundwater discharges typically result from construction site dewatering, deep excavations, basement infiltration, borehole installation, testing and site remediation. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. Should the Local Planning Authority be minded to approve the planning application, Thames Water would like the following informative attached to the planning permission: "A Groundwater Risk Management Permit from Thames Water will be required for discharging groundwater into a public sewer. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 020 3577 9483 or by emailing trade.effluent@thameswater.co.uk . Application forms should be completed on line via www.thameswater.co.uk. Please refer to the Wholesale; Business customers; Groundwater discharges section.

With regard to SURFACE WATER drainage, Thames Water would advise that if the developer follows the sequential approach to the disposal of surface water we would have no objection. Management of surface water from new developments should follow guidance under sections 167, 168 & 169 in the National Planning Policy Framework. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. Should you require further information please refer to our website. <https://www.thameswater.co.uk/help/home-improvements/how-to-connect-to-a-sewer/sewer-connection-design>

Water Comments:

Water Comments:Following initial investigations, Thames Water has identified an inability of the existing water network infrastructure to accommodate the needs of this development proposal. As such Thames Water request that the following condition be added to any planning permission. No development shall be occupied until confirmation has been provided that either:- all water network upgrades required to accommodate the additional demand to serve the development have been completed; or - a development and infrastructure phasing plan has been agreed with Thames Water to allow development to be occupied. Where a development and infrastructure phasing plan is agreed no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan. Reason - The development may lead to no / low water pressure and network reinforcement works are anticipated to be necessary to ensure that sufficient capacity is made available to accommodate additional demand anticipated from the new development" The developer can request information to support the discharge of this condition by visiting the Thames Water website at thameswater.co.uk/preplanning. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (e-mail: devcon.team@thameswater.co.uk) prior to the planning application approval.

There are water mains crossing or close to your development. Thames Water do NOT permit the

building over or construction within 3m of water mains. If you're planning significant works near our mains (within 3m) we'll need to check that your development doesn't reduce capacity, limit repair or maintenance activities during and after construction, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes.

<https://www.thameswater.co.uk/developers/larger-scale-developments/planning-your-development/working-near-our-pipes>

If you are planning on using mains water for construction purposes, it's important you let Thames Water know before you start using it, to avoid potential fines for improper usage. More information and how to apply can be found online at [thameswater.co.uk/buildingwater](https://www.thameswater.co.uk/buildingwater).

Thames Water recommend the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Supplementary Comments:

Yours faithfully,
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ,
Email: devcon.team@thameswater.co.uk