



Heat Geek Installations Ltd.

63 Bermondsey Street, London, SE1 3XF

MCS: IAA-10057

RECC: 00075650

Trustmark: 3147435

MCS 020 Noise Assessment Results

Homeowner Details	
Customer	Phill Dettman
Installation address	137 London Road, Reading, RG10 9HA

Installation Details	
ASHP	Vaillant aroTHERM plus 12kW
Installation address	137 London Road, Reading, RG10 9HA

Assessment Details	
Date Created	8 Feb 2025
Assessment Zone	Assessment position1
Heat Pump Sound Power Level	60dB(A)
Noise Barrier	Partial
Directivity	4Q
Distance to Assessment position	12.00
Calculated noise level	40.500dB(A)
Deemed Pass MCS020	Yes

For any queries regarding this information, please get in touch with us at upgrades@heatgeek.com or 0808 168 9403