

Date: 10 December 2024
Application: 242773



**WOKINGHAM
BOROUGH COUNCIL**

WBC Drainage

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Drainage,

Full Planning Approval Consultation

Application Number: 242773

Applicant: Mr & Mrs Mead

Site Address: Tiryns, Forest Road, Binfield, Wokingham, RG40 5QR

Parish: St. Nicholas Hurst

Grid Reference: Easting - 480630, Northing - 170935

Type of Development: Minor Dwellings (1-9)

Proposal: Full application for the proposed erection of 1no. 4 bedroom residential dwelling following demolition of the existing dwelling and outbuildings.

Case Officer: Tariq Bailey-Biggs

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 242773. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	Boniface Ngu Flood Risk & Drainage		
Service	WBC Drainage	App No:	242773
Address:	Tiryns, Forest Road, Binfield, Wokingham, RG40 5QR.		
Proposal:	Full application for the proposed erection of 1no. 4 bedroom residential dwelling following demolition of the existing dwelling and outbuildings.		
Type of Development:	Minor Dwellings (1-9)		
Site Visit Made:	No		

Summary Of Recommendations

- ☐ No comment
- ☐ No objection
- ☒ No objection subject to conditions (and reasons) **stated below**
- ☐ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

The site is within flood zone 1 and we would have no objection to the principle of the development as represented by **proposed location and site plan drawing 23-104-10A dated October 2024.**

The **application form** states that surface water runoff will be managed by SuDS while foul will be managed via a package treatment plant.

As drainage details have not been provided, we would **recommend the condition below:**

Conditions & Reasons (if required)

No development shall take place until full details of the drainage system for the site have been submitted to and approved in writing by the LPA. The details shall include:

1. Calculations indicating the existing runoff rate from the site.
2. BRE 365 test results demonstrating whether infiltration is achievable or not.
3. Use of SuDS following the SuDS hierarchy, preferably infiltration.
4. Full calculations demonstrating the performance of soakaways or capacity of attenuation features to cater for 1 in 100-year flood event with a 40% allowance for climate change and runoff controlled at existing rates, or preferably better.

5. Groundwater monitoring confirming seasonal high groundwater levels in the area.
6. A drainage strategy plan indicating the location and sizing of SuDS features, with the base of any SuDS features located at least 1m above the seasonal high water table level.
7. Details demonstrating how any SuDS for this development would be managed throughout the lifespan of the development and who will be responsible for maintenance.

The approved scheme shall be implemented prior to the first occupation of the development and shall be maintained in the approved form for as long as the development remains on the site.

This is to prevent increased flood risk from surface water run-off. Relevant policy: NPPF (2023) Section 14 (Meeting the Challenge of Climate Change, Flooding and Coastal Change), Core Strategy policy CP1 and Managing Development Delivery Local Plan policies CC09 and CC10.

Date:	11/12/2024	Signed:	Boniface Ngu
--------------	------------	----------------	--------------