

Date: 27 February 2025
Application: 250461



**WOKINGHAM
BOROUGH COUNCIL**

WBC Highways

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Highways,

Householder Consultation

Application Number: 250461

Applicant: Mr&Mrs Crabtree

Site Address: 6 Barber Close, Hurst, Wokingham, RG10 0RZ

Parish: St. Nicholas Hurst

Grid Reference: Easting - 479281, Northing - 173446

Type of Development: Other Householder

Proposal: Householder application for the proposed two storey side extension. Plus, changes to fenestration. Following the demolition of the existing single storey extension.

Case Officer: Tariq Bailey-Biggs

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 250461. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	JP		
Service	WBC Highways	App No:	250461
Address:	6 Barber Close, Hurst, Wokingham, RG10 0RZ.		
Proposal:	Householder application for the proposed two storey side extension. Plus, changes to fenestration. Following the demolition of the existing single storey extension.		
Type of Development:	Other Householder		
Site Visit Made:	Yes/No		

Summary Of Recommendations

- ☐ No comment
- ☒ No objection
- ☐ No objection subject to conditions (and reasons) **stated below**
- ☐ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

The proposal will increase the numbers of habitable rooms from 7 to 9. As the garage of dimensions 5.5m x 5.4m does not fully meet the council's requirement for car parking, it will not be counted towards parking provisions.

According to the WBC Car Parking Standards, the development of such scale in Village location will require three parking within the red line boundary. Each parking space shall have minimum dimensions of 5.0m x 2.5m.

The driveway will have ample spaces for more than three driveway parking, which is acceptable.

No negative impacts on abilities for cycle storage are expected, which is acceptable.

Conditions & Reasons (if required)

Date:	27/2/2025	Signed:	JP
--------------	-----------	----------------	----