

**Central Hub Fire Safety Office, Wokingham Fire Station, 11-13
Easthampstead Road, Wokingham, Berkshire, RG40 2EH
Email: centralhubfiresafety@rbfrs.co.uk
Switchboard 0118 945 2888
Royal Berkshire Fire and Rescue Service 🌐 rbfrs.co.uk**



Head of Planning
planning.enquiries@wokingham.gov.uk

Your ref 260779
Our ref 521365
Ask for Amy Mendham
Date 28 April 2026

Dear Sir or Madam,

Re: Town and Country Planning Act 1990 (as amended)

Further to your letter dated 15 April 2026 and enclosed plan/s which you have forwarded, it is noted that your application for the approval of reserved matters pursuant to outline planning consent 223458 (as amended by applications 242641 and 250553), for the Revised access off Duffield Road plus associated modifications to Sonning Golf Club, including reconfiguration of the golf club parking areas and conversion of the west wing of the existing clubhouse to accommodate a new golf simulator practice facility, including removal of external staircase and changes to fenestration (Phase 1) has been made under the Town and Country Planning Acts.

At this stage there is no duty placed upon the Fire Authority under the aforementioned legislation to make any comment relative to your application.

Any structural fire precautions and all means of escape provision will have to satisfy Building Regulation requirement. These matters are administered by the local authority Building Control or approved inspectors, who you are advised to contact in this regard.

Please be advised that any comments made by the Fire Authority in this letter must not be taken as formal approval that your plan/s confirm to the requirements and recommendations of current Guides or Codes of Practice for means of escape in case of fire.

Recommendations identified under Section B5 of Approved Document B

Summary

At this stage of the planning application, Royal Berkshire Fire and Rescue Service makes comment relating to Section B5 of Approved Document B. This section specifies the

Chief Fire Officer – Mark Arkwell

provision of facilities to assist firefighters within the building and to enable fire appliances to gain access to the building externally.

Complying with these requirements, in advance of the formal statutory Building Regulation consultation process, will assist that process and the following recommendations are made without prejudice to that process

Access and facilities for the Fire and Rescue Service

Full guidance criteria is published in Approved Document B accessed via web link:

<https://www.gov.uk/government/publications/fire-safety-approved-document-b>

Automatic water-based suppression system

The nature of the proposal gives reason for the Fire Authority to strongly advise the consideration of an appropriate automatic water-based suppression system for the proposed premises. Automatic water-based suppression systems can significantly reduce the risk to life and mitigate the damage caused by fire.

The case for installing automatic water-based suppression systems is compelling; they save lives, reduce injuries, protect property and increase sustainability. Over the past few years, there has been a growing recognition of the effectiveness of automatic water-based suppression system in domestic premises.

Further information on the benefits of automatic water-based suppression systems and how they can play a significant role in saving life and property from the devastating effects of fire is available on the following websites:

www.nfsn.co.uk

National Fire Sprinkler Network

www.firesprinklers.info

Fire Sprinkler Association

www.bafsa.org.uk

British Automatic Fire Sprinkler Association

www.rbfrs.co.uk

Royal Berkshire Fire and Rescue Service

Water supplies for firefighting

Consideration is to be given to the *National Guidance Document on the Provision of Water for Firefighting* and the specific advice of this Fire Authority on the location of fire hydrants.

Yours faithfully,



Amy Mendham

Chief Fire Officer – Mark Arkwell

Authorised Fire Safety Inspector
And on behalf of the Royal Berkshire Fire Authority

Chief Fire Officer – Mark Arkwell

ROYAL BERKSHIRE
FIRE AND RESCUE SERVICE

