

TACTILE PAVING PEDESTRIAN CROSSING POINT AWAY FROM JUNCTIONS

SCALE 1:25



TACTILE PAVING PEDESTRIAN CROSSING AT JUNCTION

SCALE 1:25



TACTILE PAVING PEDESTRIAN CROSSING



TYPICAL TRAPPED GULLY DETAIL

SCALE 1:10



STANDARD KERB TYPE HB2

SCALE 1:10



BULLNOSE KERB TYPE BN

SCALE 1:10



INVERTED KERB TYPE BN

SCALE 1:10



PCC EDGING TYPE EF

SCALE 1:10

© ABLEY LETCHFORD PARTNERSHIP LTD.
This drawing should not be reproduced without consent.

GENERAL NOTES:

1. This drawing is to be read in conjunction with and checked against all other drawings, Engineering details, Specification and any structural, Geotechnical or other specialist document provided.
2. Any anomaly or contradiction between any of the above is to be reported to the Engineer.
3. WBC Highway Inspector to be present during inspections/CBR testing.
4. Gratings and frames shall be to BS EN124 1994.
   Ref. Class D400 Trafficked areas.
   Ref. Class C250 footways only.
   Large gratings may only be used by the approval of the overseeing organisation.
   Dished gratings permissible in footways only.
5. Dowel bars may be required with standard kerbs in circumstances where the kerbs are vulnerable
6. Blocks shall normally be bedded on 50 sharp sand complying with BS 882 grading C or M.
7. In areas where the blocks may be trafficked, or narrow strips of paving are used as a feature, the sand must be substituted by 30 mortar to designation (ii) or (iii) laid on CMB3 concrete.
8. Flags shall be bedded on 30 mortar to designation (ii) or (iii).
9. The laying arrangement shown of tactile slabs are indicative only and shall be in accordance with Guidence on the use of Tactile Paving Surfacing DETR. When the dropped kerb is in direct line of travel the tactiles surface shall be laid to a depth of 1200mm
10. Crossing kerbs shall be flush with the carriageway where tactile flags are used.

Rev	Date	Description	Drawn	Checked
B	02.26	Title box updated with current logo	RP	DS
A	06.24	First Issue	LC	DS

Abley Letchford

www.ableyletchford.co.uk

Client

BELLWAY HOMES

Project

LAND NORTH OF ARBORFIELD ROAD, SHINFIELD

Title

FULL APPLICATION HIGHWAY CONSTRUCTION DETAILS SHEET 2

Status

Scale	Date	Drawn	Checked
AS SHN @ A1	JUNE 2024	LC	DS

Drawing No	Revision
HD008-FA-652	B