

Job no:	9275
Date:	21/08/2026
Assessor name:	Joshua Collett
Registration no:	W327-0001
Development name:	Park Lane, Charvill

Dwelling Type:	1	2	3	4	5	6	7	8	9	10
Dwelling type description:	Walker HT									
WC	17.64	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Taps (excluding kitchen taps)	9.48	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bath	17.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Shower	39.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Kitchen sink taps	13.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Washing machine	17.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Dishwasher	4.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Waste Disposal Unit	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Water Softener	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Contribution from Greywater										
Contribution from Rainwater										
Contribution from Grey/Rainwater (combined system)										
Normalisation factor	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91
Total Water Consumption	107.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Code for Sustainable Homes - credits awarded	2	0	0	0	0	0	0	0	0	0
CSH Mandatory Level	Level 1/2	-	-	-	-	-	-	-	-	-
External Water Use	5	5	5	5	5	5	5	5	5	5
17. K - Litres/person/day	112.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
17. K Compliance?	Yes	-	-	-	-	-	-	-	-	-

BRE Global 2010. BRE Certification is a registered trademark owned by BRE Global and may not be used without BRE Global's written permission. Permission is given for this tool to be copied without infringement of copyright for use only on projects where a Code for Sustainable Homes assessment is carried out. Whilst every care is taken in preparing the Wat 1 assessment tool, BREG cannot accept responsibility for any inaccuracies or for consequential loss incurred as a result of such inaccuracies arising through the use of the Wat 1 tool.

PRINTING: before printing please make sure that in "Page Setup" you have selected the page to be as "Landscape" and that the Scale has been set up to 80% (maximum)