

Date: 30 July 2025
Application: 251813



**WOKINGHAM
BOROUGH COUNCIL**

WBC Highways

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Highways,

Householder Consultation

Application Number: 251813

Applicant: Mr and Mrs Loudon

Site Address: 84 Old Bath Road, Charvil, Wokingham, RG10 9QL

Parish: Invalid code

Grid Reference: Easting - 477731, Northing - 175956

Type of Development: Other Householder

Proposal: Householder application for a proposed single storey side and rear extension, following the removal of a tandem garage block.

Case Officer: Marcus Hillman

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 251813. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	JP		
Service	WBC Highways	App No:	251813
Address:	84 Old Bath Road, Charvil, Wokingham, RG10 9QL.		
Proposal:	Householder application for a proposed single storey side and rear extension, following the removal of a tandem garage block.		
Type of Development:	Other Householder		
Site Visit Made:	Yes/No		

Summary Of Recommendations

- ☐ No comment
- ☒ No objection
- ☐ No objection subject to conditions (and reasons) **stated below**
- ☐ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

There is no net increase in the numbers of habitable rooms and the existing driveway will be retained. As the existing garage does not fully meet the council's requirement for car parking, there will be no loss of parking space.

It is therefore expected that there will be no additional demand for car parking and no reduction in parking provisions.

The 1m wide side access of the dwelling will provide direct access to the rear for cycle storage, which is acceptable.

Conditions & Reasons (if required)

Date:	1/8/2025	Signed:	JP
--------------	----------	----------------	----