



© ABLEY LETCHFORD PARTNERSHIP LTD.
This drawing should not be reproduced without consent.

- STREET LIGHTING NOTES:**
1. Do not scale.
 2. This drawing is to be read in conjunction with and checked against all other drawings, Engineering details, Specification and any structural, Geotechnical or other specialist document provided.
 3. Any anomaly or contradiction between any of the above is to be reported to the Engineer.
 4. Lighting design to be in accordance with the Highway Authority and the Manufacturer's specification.

STREET LIGHTING KEY:

- ADOPTABLE LIGHTING:**
- Proposed 6m Aluminium lighting company conical tapered column with post top mounted Philips Lumina Gen 2 Micro RSP202, DM10 Optic with BL1 rear louvre, 10 LED, 2700K and 3200 lumen output. Lantern to be installed with 0 degree tilt.
 - (R&L Denotes Raise and Lower Columns)
 - Direction of fall for Raise and Lower columns
 - Proposed Link Road street lighting column. TBC.
 - Existing street lighting column. TBC.

LIGHTING LUX KEY:

- 0.6 Lux Contour (Min. for PS)
- Adoptable areas fit to Lighting Class PS in accordance with BS EN 13201-2015.

LIGHTING NOTES:

1. Private lighting NOT controlled by WBC Telesma CMS System.
2. Control / Dimmer Unit to be Telesma 5-pin NEMA Tolexcell with integral Telesma Dimming Module (DALI standard) and GPS positioning.
3. Cut-Out Type - Lucy MC0405LF with 6 amp R&L.C. fuse as standard. Fuse size may be increased as appropriate where feeds to other units are required - fuse size to conform to IEE regulations).
4. Isolator - Charles Manufacturing LSI-02/5F or Lucy Triplan Mini isolation unit with 6 amp

B	26.25	UPDATED TO SUIT LATEST LAYOUT	CL	RF
A	02.25	FIRST ISSUE	AB	RF
Rev	Draw	Description	Drawn	Checked



Client
MILLER HOMES

Project
**SOUTH WOKINGHAM SDL
PHASE 2B R10 RESERVED
MATTERS APPLICATION**

File
**STREET LIGHTING
LUX PLAN**

Scale	Date	Drawn	Checked
1:500 @ A0	FEB 2025	AS	RF
Drawing No	Project		
A389-R10-RM-121	B		

Scale 1:500
0 5 10 15 20 25m