

3rd Party Planning Application – 251260

Wokingham District Council, P.O Box 157, , WOKINGHAM, Berks, RG40 1WR

08 July 2025

Our DTS Ref: 79227

Your Ref: 251260

Dear Sir/Madam,

Re: HEATHLANDS FARM, HONEY HILL, -, WOKINGHAM, -, RG40 3BG

Waste Comments:

Waste Comments: With the information provided, Thames Water has been unable to determine the Foul water infrastructure needs of this application. Thames Water has contacted the developer in an attempt to obtain this information and agree a position for FOUL WATER drainage, but have been unable to do so in the time available and as such, Thames Water request that the following condition be added to any planning permission. “No development shall be occupied until confirmation has been provided that either:- 1. Foul water Capacity exists off site to serve the development, or 2. A development and infrastructure phasing plan has been agreed with the Local Authority in consultation with Thames Water. Where a development and infrastructure phasing plan is agreed, no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan, or 3. All Foul water network upgrades required to accommodate the additional flows from the development have been completed. Reason - Network reinforcement works may be required to accommodate the proposed development. Any reinforcement works identified will be necessary in order to avoid sewage flooding and/or potential pollution incidents. The developer can request information to support the discharge of this condition by visiting the Thames Water website at thameswater.co.uk/preplanning. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (e-mail: devcon.team@thameswater.co.uk) prior to the planning application approval.

The application indicates that SURFACE WATER will NOT be discharged to the public network and as such Thames Water has no objection, however approval should be sought from the Lead Local Flood Authority. Should the applicant subsequently seek a connection to discharge surface water into the public network in the future then we would consider this to be a material change to the proposal, which would require an amendment to the application at which point we would need to review our position.

Water Comments:

Water Comments: With regard to water supply, this comes within the area covered by the South East Water Company. For your information the address to write to is - South East Water Company, Rocfort Road, Snodland, Kent, ME6 5AH, Tel: 01444-448200

Supplementary Comments:

Thames Water advise that a drainage strategy should contain the points of connection to the public sewerage system as well as the anticipated flows (including flow calculation method) into the proposed connection points. This data can then be used to determine the impact of the proposed development on the existing sewer system. If the drainage strategy is not acceptable Thames Water will request that an impact study be undertaken.

Yours faithfully,
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ,
Email: devcon.team@thameswater.co.uk