

- Notes:**

GENERAL

1. THIS DRAWING IS FOR PLANNING PURPOSES. CONSULT ALL UTILITY PLANS BEFORE ANY EXCAVATIONS.

2. THIS DRAWING DOES NOT INTEND TO IDENTIFY THE EXACT POSITION OF THE EXISTING APPARATUS. LOCATION OF THE EXISTING APPARATUS MUST IN ALL CASES BE IDENTIFIED BY CONSULTING THE RELEVANT NETWORK OWNERS IN THE AREA.

SITE LAYOUT

THIS DRAWING IS BASED UPON THE LATEST LAYOUT PROVIDED BY THE DEVELOPER: P1572 CSL00-Combined Site Layout - 6

PROPOSED MAINS

1. ROAD CROSSINGS TO BE IN DUCT PROVIDED BY THE DEVELOPER, LAID AS PER THE SPECIFIC SECTION DETAILS FOR THE JOB.

PROPOSED SERVICES

7. ALL SERVICES TO BE DUCTED.

30mm DUCT TO BE UTILIZED FOR SINGLE PHASE SERVICES. DUCT TO BE LAID BY THE DEVELOPER AT 400mm COVER TO THE FINISHED LEVEL.

50mm DUCT TO BE UTILIZED FOR THREE PHASE SERVICES. DUCT TO BE LAID BY THE DEVELOPER AT 400mm COVER TO THE FINISHED LEVEL.

100mm DUCT TO BE UTILIZED FOR SINGLE PHASE OR THREE PHASE SERVICE ROAD CROSSING. DUCT TO BE LAID BY THE DEVELOPER AT 600mm COVER TO THE FINISHED LEVEL.

8. IT IS RESPONSIBILITY OF THE DEVELOPER TO ENSURE THAT ALL SERVICE ROUTES ARE WITHIN THE DEMISE OF THE PROPERTY BEING SUPPLIED AND THE LOCATION OF ALL DUCTS ARE CLEARLY MARKED.

9. ALL SERVICES ROAD CROSSINGS TO BE SEPARATELY DUCTED WITH THEIR POSITIONS CLEARLY MARKED.

LEGEND

33kV PROPOSED CABLE
11kV EXISTING CABLE
11kV PROPOSED CABLE
WATER EXISTING MAIN
WATER PROPOSED MAIN
LV EXISTING CABLE
LV PROPOSED CABLE
LV PROPOSED DUCTED SERVICE

● LV SERVICE JOINT
● LV MAIN JOINT
● 11kV JOINT
✕ LIGHTING COLUMN
✕ FEEDER PILLAR
● BOTTLE END & EARTH ROD
● ELECTRIC VEHICLE CHARGING / PHOTO VOLTAIC CELLS

● L1
● L2
● L3

METER LOCATION / PHASES
● ASSUMED METER LOCATION

UNAPPROVED CONSTRUCTION DRAWING

SCALE BAR

0m 10m 20m 30m 40m 50m 60m 70m 80m 90m 100m

SECTION VIEWPORT

06 AMENDED RC UNAPP 08/11/24

05 DUCTWORK SECTIONS UPDATED, SECTIONS ADDED TO LAYOUT RC UNAPP 08/11/24

04 PLOTS GROUPED, EXISTING HV MAIN ADDED TN UNAPP 17/10/24

03 125M SUBSTATION RADIUS RC UNAPP 14/10/24

02 UPDATE TO MAINS LAYOUT RC UNAPP 11/10/24

01 CROSS SECTIONS UPDATED, EARTH ADDED MG UNAPP 28/08/24

00 FIRST DRAFT MG UNAPP 23/08/24

REV: DESCRIPTION BY: STATUS: DATE:

SSEN: EXX577


Connect it Utility Services
Utility Connections www.clus.co.uk

IDP: DETAILS
CONNECT IT UTILITY SERVICES LTD
FOUNDATION HOUSE
UNIT C (WEST) HAMILTON BUSINESS PARK
SOUTHAMPTON
SO30 2JR

SITE:
SOUTH WOKINGHAM
OFF WATERLOO ROAD
RG40 3AD

TITLE:
ELECTRIC CONSTRUCTION PLAN 4/4

SCALE: AT A0: 1:2000 DATE: 23/08/24 DRAWN: MG CHECKED: WK
DRAWING NO: MU3612-E004 CUS NO: MU3612 REVISION: 06



GENERAL

1. THIS DRAWING IS FOR PLANNING PURPOSES. CONSULT ALL UTILITY PLANS BEFORE ANY EXCAVATIONS.

NOTES:

2. THIS DRAWING DOES NOT INTEND TO IDENTIFY THE EXACT POSITION OF THE EXISTING APPARATUS. LOCATION OF THE EXISTING APPARATUS MUST IN ALL CASES BE DETERMINED BY CONSULTING THE RELEVANT NETWORK OWNERS IN THE AREA.

SITE LAYOUT

THE DRAWING IS BASED UPON THE LATEST LAYOUT PROVIDED BY THE DEVELOPER: P1572.CSL.00-Combined Site Layout -6

PROPOSED MAINS

1. ROAD CROSSINGS TO BE IN DUCT PROVIDED BY THE DEVELOPER. LAID AS PER THE SPECIFIC SECTION DETAILS FOR THE JOB.

PROPOSED SERVICES

1. ALL SERVICES TO BE DUCTED.
-30mm DUCT TO BE UTILIZED FOR SINGLE PHASE SERVICES. DUCT TO BE LAID BY THE DEVELOPER AT 450mm COVER TO THE FINISHED LEVEL.
-50mm DUCT TO BE UTILIZED FOR THREE PHASE SERVICES. DUCT TO BE LAID BY THE DEVELOPER AT 450mm COVER TO THE FINISHED LEVEL.
-100mm DUCT TO BE UTILIZED FOR SINGLE PHASE OR THREE PHASE SERVICE ROAD CROSSING. DUCT TO BE LAID BY THE DEVELOPER AT 600mm COVER TO THE FINISHED LEVEL.

2. IT IS RESPONSIBILITY OF THE DEVELOPER TO ENSURE THAT ALL SERVICE ROUTES ARE WITHIN THE DEMISE OF THE PROPERTY BEING SUPPLIED AND THE LOCATION OF ALL DUCTS ARE CLEARLY MARKED.

3. ALL SERVICES ROAD CROSSINGS TO BE SEPARATELY DUCTED WITH THEIR POSITIONS CLEARLY MARKED.

The site layout plan shows a rectangular plot with various utility lines and structures. Dimensions are given in meters. Existing cables include 33kV and 11kV. Proposed services include 33kV, 11kV, water, and LV. The plan also indicates locations for LV joints, lighting columns, feeder pillars, bottle ends, earth rods, EV charging stations, meter locations, and assumed meter locations.

06	SECTION VIEWPORT AMENDED	RC	UNAPP.	08/11/24
05	DUCTWORK SECTIONS UPDATED, SECTIONS ADDED TO LAYOUT	RC	UNAPP.	08/11/24
04	PLOTS GROUPED, EXISTING HV MAIN ADDED	TN	UNAPP.	17/10/24
03	250M SUBSTATION RADIUS	RC	UNAPP.	14/10/24
02	UPDATE TO MAINS LAYOUT	RC	UNAPP.	11/10/24
01	CROSS SECTIONS UPDATED, EARTH ADDED	MQ	UNAPP.	28/08/24
00	FIRST DRAFT	MQ	UNAPP.	23/08/24
REV	DESCRIPTION:	BY:	STATUS:	DATE:
SSEN: EXX577				

CONNECT it

Utility Services

Utility Connections

www.cius.co.uk

ICP DETAILS

CONNECT IT UTILITY SERVICES LTD
FOUNDATION HOUSE
UNIT C (WEST) HAMILTON BUSINESS PARK
SOUTHAMPTON
SO30 2JR

SITE:

SOUTH WOKINGHAM
OFF WATERLOO ROAD
RG40 3AD

TITLE:

ELECTRIC CONSTRUCTION PLAN 4/4

SCALE: A1 1:2000

DATE: 23/08/24

DRAWN: MQ

CHECKED: WK

DRAWING NO: MUM316-E004

CUS NO: MUM316

REV: 06