

PLANNING REF : 250286
PROPERTY ADDRESS : 32 Easby Way
: Lower Earley, Reading
: RG6 3XA
SUBMITTED BY : Mr William Luck
DATE SUBMITTED : 22/02/2025

COMMENTS:

Can the applicant confirm that the proposed garage will have an internal size in accordance with WBC's standards, ie clear width of 3m and a clear depth of 6m? If so, can the parking space proposed at the side still be accommodated?