

Date: 16 September 2024
Application: 242058



WOKINGHAM
BOROUGH COUNCIL

WBC Drainage

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Drainage,

Full Planning Approval Consultation

Application Number: 242058

Applicant: Mr James Whittingham

Site Address: Oakview, Mill Lane, Sindlesham, Wokingham, RG41 5DF

Parish: Winnersh

Grid Reference: Easting - 477295, Northing - 169988

Type of Development: Minor Dwellings (1-9)

Proposal: Full application for proposed erection of 1 No detached dwelling with associated landscaping and parking followed by the demolition of the existing outbuildings.

Case Officer: James Fuller

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 242058. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	Boniface Ngu Flood Risk & Drainage		
Service	WBC Drainage	App No:	242058
Address:	Oakview, Mill Lane, Sindlesham, Wokingham, RG41 5DF.		
Proposal:	Full application for proposed erection of 1 No detached dwelling with associated landscaping and parking followed by the demolition of the existing outbuildings.		
Type of Development:	Minor Dwellings (1-9)		
Site Visit Made:	No		

Summary Of Recommendations

- ☐ No comment
- ☐ No objection
- ☒ No objection subject to conditions (and reasons) **stated below**
- ☐ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

The site is within flood zone 1 and in an area that experiences low risk surface water flooding.

We would have no objection to the principle of the dwelling, as represented by **planning drawings PL-101**.

The **application form** proposes surface water management via soakaway and foul water management via a package treatment plant.

As drainage details have not been provided, we would **recommend the condition below**:

Conditions & Reasons (if required)

No development shall take place until full details of the drainage system for the site have been submitted to and approved in writing by the LPA. The details shall include:

1. BRE 365 test results demonstrating that infiltration is achievable.
2. Full calculations demonstrating the performance of soakaways.
3. A demonstration of how surface water runoff is going to be catered for, given that parts of the development site already suffer from surface water flooding.

4. A description of how the proposed development will deal with surface water overland flows.
5. Groundwater monitoring confirming seasonal high groundwater levels in the area.
6. Details of the foul drainage for the development.
7. A drainage strategy plan indicating the location and sizing of SuDS features, with the base of any SuDS features located at least 1m above the seasonal high water table level.
8. Details demonstrating how any SuDS for this development would be managed throughout the lifespan of the development and who will be responsible for maintenance.

The approved scheme shall be implemented prior to the first occupation of the development and shall be maintained in the approved form for as long as the development remains on the site.

This is to prevent increased flood risk from surface water run-off. Relevant policy: NPPF (2023) Section 14 (Meeting the Challenge of Climate Change, Flooding and Coastal Change), Core Strategy policy CP1 and Managing Development Delivery Local Plan policies CC09 and CC10.

Date:	17/09/2024	Signed:	Boniface Ngu
--------------	------------	----------------	--------------