

Date: 16 August 2024
Application: 242049



**WOKINGHAM
BOROUGH COUNCIL**

WBC Highways

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Highways,

Variation/Removal of Condition Consultation

Application Number: 242049

Applicant: Mrs R Ruscoe

Site Address: Travis Perkins Site, Woodley Green, Woodley, Wokingham, RG5 4QP

Parish: Woodley

Grid Reference: Easting - 476851, Northing - 173468

Type of Development: Major All other developments

Proposal: Application to vary condition 2 of planning consent 233168 for the proposed erection of a building to form a residential care home (Use Class C2) with access, parking, landscaping and associated works, following demolition of all existing buildings on the site. Condition 2 refers to the approved details and the variation is to reposition and amend the frontage of the building to accommodate manhole access.

Case Officer: Stefan Fludger

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 242049. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	JP		
Service	WBC Highways	App No:	242049
Address:	Travis Perkins Site, Woodley Green, Woodley, Wokingham, RG5 4QP.		
Proposal:	Application to vary condition 2 of planning consent 233168 for the proposed erection of a building to form a residential care home (Use Class C2) with access, parking, landscaping and associated works, following demolition of all existing buildings on the site. Condition 2 refers to the approved details and the variation is to reposition and amend the frontage of the building to accommodate manhole access.		
Type of Development:	Major All other developments		
Site Visit Made:	Yes/No		


Summary Of Recommendations

- ☐ No comment
- ☐ No objection
- ☐ No objection subject to conditions (and reasons) **stated below**
- ☒ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

The proposal seeks consents for varying the approved details of the manhole access, the frontage of the building 1.5m to the East, area of some rooms, path at the site frontage and landscaping for Planning Application Reference 233168.

The revised plans indicate no changes in the demand of parking, parking provisions and ability for cycle storage. Highways have concern regarding the narrowest point of the footway is reduced to 1.1m. As the footway will provide access to the garden, 1.1m wide is insufficient.



With low traffic anticipated for the disabled parking spaces, the applicant shall consider converting the above section of road into shared surface, to remove the level differences between the footway and carriageway.

Conditions & Reasons (if required)

Date:	19/8/2024	Signed:	JP
--------------	-----------	----------------	----