

Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 1 of 16

230633

Barkham Solar Farm

On behalf of: Bouygues E&S Infrastructure UK Limited
P01



Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 2 of 16

	Originated by	Checked by	Reviewed by
Original	G. Saska	R. Lovas	Sz. Skerhak
Approved by	E. Hocking	As Project Manager, I confirm that the below document(s) have been subjected to Catsurveys' Check and Review procedure and that I approve them for issue	
Date	19/12/2023		

This report should be read in conjunction with:

PAS 128:2014 'Specification for underground utility detection, verification and location.'

TSA Guidance Note - The Essential Guide to Utility Surveys

HSG 47 - Avoiding Dangers from Underground Services

Project drawing(s)

Catsurveys Ltd

This document has been prepared by Catsurveys Ltd in its professional capacity as consultants in accordance with the terms and conditions of Catsurveys Ltd contract with the commissioning party (the "Client"). Regard should be had to those terms and conditions when considering and/or placing any reliance on this document. No part of this document may be copied or reproduced by any means without prior written permission from Catsurveys Ltd. If you have received this document in error, please destroy all copies in your possession or control and notify Catsurveys Ltd.

Any advice, opinions, or recommendations within this document (a) should be read and relied upon only in the context of the document as a whole; (b) do not, in any way, purport to include any manner of legal advice or opinion; (c) are based upon the information made available to Catsurveys at the date of this document and on current UK standards, codes, technology and construction practices as at the date of this document. It should be noted and it is expressly stated that no independent verification of any of the documents or information supplied to Catsurveys has been made. No liability is accepted by Catsurveys for any use of this document, other than for the purposes for which it was originally prepared and provided. Following final delivery of this document to the Client, Catsurveys will have no further obligations or duty to advise the Client on any matters, including development affecting the information or advice provided in this document.

This document has been prepared for the exclusive use of the Client and unless otherwise agreed in writing by Catsurveys, no other party may use, make use of or rely on the contents of this document. Should the Client wish to release this document to a third party, Catsurveys may, at its discretion, agree to such release provided that (a) Catsurveys' written agreement is obtained prior to such release; and (b) by release of the document to the third party, that third party does not acquire any rights, contractual or otherwise, whatsoever against Catsurveys Ltd, accordingly, assume no duties, liabilities or obligations to that third party; and (c) Catsurveys accepts no responsibility for any loss or damage incurred by the Client or for any conflict of Catsurveys' interests arising out of the Client's release of this document to the third party.

Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 3 of 16

Table of Contents

1 Preambles	4
1.1 Task team	4
1.2 Risk Assessments / Method Statements and Safety	5
1.3 Equipment Information	5
2 Survey Scope	6
2.1 Survey Area	7
2.2 Desktop Utility Records Search (DURS)	8
3 Site Specific Observations	8
4 Survey Results	9
4.1 Results Summary	9
5 Additional Information	14
5.1 What is Utility Detection and Mapping?	14
5.2 What is PAS 128?	15
5.3 Benefits of a Utility Detection Survey (Survey Type B)	15
5.4 Limitations of Current Technology	15
6 Accuracy Compliance	15
6.1 General	15
6.2 Examples of Mains and / or Services that can be detected	16
6.3 Advisory Note	16
6.4 Calibration Procedures and Records	16
6.5 Horizontal and Vertical Accuracy	16

Table of Figures

Figure 1- Underground Utility Detection and Topographical Survey	7
Figure 2 – Gigaclear underground utility	11
Figure 3 – Gigaclear underground utility and survey area	12
Figure 4 – SGN underground utility	12
Figure 5 – SGN underground utility and survey area	12

Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 4 of 16

1 Preambles

1.1 Task team

Project team	Position
E. Hocking	Project Manager
L. Tullock	Assistant Utility Surveyor
R. Tullock	Telecoms Surveyor
T. Horvath	Operations Manager
R. Lovas	Project Owner
Sz. Skerhak	BIM Specialist
G. Saska	CAD Technician

Survey Date	27.11.2023-30.11.2023.
-------------	------------------------

Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 5 of 16

1.2 Risk Assessments / Method Statements and Safety

Prior to attending site, associated risk assessments and method statements were provided to the client and briefed to all survey staff attending works. A point of work risk assessment would have also been completed daily for the works undertaken to allow changes to be recorded dynamically which is our standard practice and are available on request.

All survey staff attending site are provided with suitable and sufficient PPE for the works undertaken or alternatively specifically advised by our client. Highways liveried vehicles and fully trained personnel in the tasks they are required to undertake with suitable supervisory capacity is mandatory. Where required, inductions and other client specific training will have been attended.

1.3 Equipment Information

All operational equipment is calibrated in accordance with the specification and manufacturers certificates of conformity. Catsurveys Ltd is accredited by the BSI to BS EN ISO 9001.

Equipment	Manufacturer	Model	Operator
Electromagnetic Locator	Radiodetection	RD8100	R.T, L.T.
Genny	Radiodetection	TX-10	R.T, L.T.
Ground Penetrating Radar	MALÅ	Opera Duo	R.T, L.T.
GPS	GeoMax	Zenith 16	R.T, L.T.

Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 6 of 16

2 Survey Scope

To carry out a topographical survey, non-intrusive underground utility survey using Electro Magnetic Location (EML) and Ground Penetrating Radar (GPR) within the survey boundary.

3. SPECIFICATIONS / STANDARDS			
Topographical:	CATSURVEYS	Utility:	CATSURVEYS
Geotechnical:	N/A	Level(s) Of Detail (LOD):	LOD 0
Composite:	N/A	Other:	N/A
4. SPECIAL REQUIREMENTS			
Site Induction Required:	NO	SAP Required:	NO
Out of Hours Working Required:	NO	Pre-site medical/Fit for work required:	NO
8. UTILITY SURVEY INFORMATION			
PAS Detection Method:	M2	PAS Quality Level Aim:	B1
EML:	YES	GPR:	YES
MGPR:	NO	CCTV:	YES
MH Cards required:	NO	MH Card type:	N/A
Mains:	YES	Services to properties:	NO
Drainage survey method:	SONDE	Services to properties (drainage):	NO
Surface Water Sonde:	YES	Services to signs and streetlights:	YES
Foul/Combined Water Sonde:	YES	Confined Space Entry:	NO
Record No. of utilities in ducts:	NO	Permitted to use spray-paint on site:	YES
9. TOPOGRAPHICAL SURVEY INFORMATION			
Topo detail level required:	TS- Full Topo		
Station points provided:	NO	Soft detail accuracy:	N/A
Above ground utilities:	YES	Hard detail accuracy:	N/A
Coordinate system:	OS NATIONAL GRID	Transformation details provided:	NO
Calculation report required:	NO	Levelling Required:	NO
GPS-Post Process:	NO	Station Point Report required:	NO

Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 7 of 16

2.1 Survey Area




Figure 1- Underground Utility Detection and Topographical Survey

 Underground Utility Detection and Topographical Survey Area

Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 8 of 16

2.2 Desktop Utility Records Search (DURS)

Utility owners have been identified within the specified survey area. A request has been made for information about the assets from the utility owners. This data has been collated as a basis for this survey and responses from the utility owners are provided within the deliverable.

These drawings have been divided to two groups: affected and unaffected. Affected utility drawings are showing utilities in the vicinity of the survey area. Unaffected utility providers have no known apparatus in the vicinity of the survey area.

Affected utility provider drawings:

- BRITISH TELECOM
- GIGACLEAR
- SCOTTISH AND SOUTHERN ELECTRICITY NETWORKS
- SGN
- THAMES WATER - SEWER
- THAMES WATER - WATER

3 Site Specific Observations

We have completed the survey to the requirements set out in the client provided specification in line with PAS 128 and our own internal Task Method Statements. There were no modifications to the survey boundary at the time of our survey and all areas were accessible without any obstructions or restrictions. Weather conditions did not adversely affect our survey results.

Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 9 of 16

4 Survey Results

This results section should be read in conjunction with the BSI guidance PAS 128: 2014 Specification for underground utility detection, verification and location. The document will support the methodologies included in this report and support the following quality levels and the associated confidence that can be invested in the detection of each utility.

Quality levels are shown within the survey data for each utility and will range from B1 to B4. Where post processing of GPR data has been requested in the scope, the utilities detected by this method will also include the letter P. For example, B1P.

EML success rates should be higher than GPR in a majority of survey areas. The techniques are very different, especially as EML techniques require cover lifting, probing and direct connection to ascertain detection where GPR only relies on radio waves applied from the surface. EML can also be applied around obstructions where GPR cannot be physically pushed, increasing its coverage. However, the combination of these methods ensure that the existing limitations of each technique are balanced.

In cases where existing records and surveyed information correlate, assumptions have been made that these are detected in the positions shown in the following results. Instances where evidence does not support the positioning of buried assets from surveyed or available records, both the detected and historic records are plotted. This represents an honest view of our findings without unrealistic assumptions being made, whilst avoiding potential hazards from buried utilities.

4.1 Results Summary

The definition for each quality level is aligned with PAS 128 when carrying out a Survey Type B / Detection survey:

All detection B1(P)-B3(P)	907	68.0 %
Total length of underground utilities within survey area (m)	1333	
Area of survey (m ²)	455892	
Average utility density (factor = length/area)	0.00	

Survey Report		catsurveys	
Barkham Solar Farm		Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey		Version: P01	Page 10 of 16

PAS128 quality level	Detection accuracy actually achieved		Length of utility detected in each quality level (m)	Percentage of total
	Horizontal 1)	Vertical 2)		
B1	±150 mm or ±15% of detected depth whichever is greater	±15% of detected depth	0	0.0 %
B1P			0	0.0 %
B1-B1P Supporting data	Horizontal and vertical location of the utility detected by multiple geophysical techniques used.			

B2	±250 mm or ±40% of detected depth whichever is greater	±40% of detected depth	883	66.2 %
B2P			0	0.0 %
B2-B2P Supporting data	Horizontal and vertical location of the utility detected by one geophysical technique used.			

B3	±500 mm	Undefined	25	1.9 %
B3P	±500 mm	Undefined	0	0.0 %
B3-B3P Supporting data	Horizontal location only of the utility detected by one or two geophysical technique(s) used.			

B4	Undefined	Undefined	0	0.0 %
B4 Supporting data	A utility segment which is suspected to exist but has not been detected and is therefore shown as an assumed route.			
B4 (Drainage)	Undefined	Undefined	425	31.9 %

1) Horizontal location is to the centreline of the utility.

2) Vertical location is to the top of the utility.

Notes:

The Quality Level “B4” contains the undetectable utilities shown on the provided utility drawings, and in addition, all those utilities, which were identified during the site survey (indicated by surface features or via manhole inspection) were classified the same quality level.

Survey Report		catsurveys	
Barkham Solar Farm		Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey		Version: P01	Page 11 of 16

Catsurveys Ltd were required to undertake a utility survey in accordance with the above scope. Using the records made available at the time of the survey to identify all utilities within the survey area the following results have been achieved.

FOUL WATER DRAINAGE				
ID	Quality Level	Detection		Survey Comments
		EML	GPR	
FWD 1	B4	No	No	Site survey identified that the possible connection point shown on the utility provider drawings has been buried. Unable to detect utility using GPR due to rough terrain on site, which makes it difficult to push the GPR unit over the surface while maintaining a consistent contact between the antenna and the ground. The buried asset would need to be made accessible in order to be surveyed.

Notes

Traffic management to assess gas and communications.



Figure 2 – Gigaclear underground utility

Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 12 of 16



Figure 3 – Gigaclear underground utility and survey area



Figure 4 – SGN underground utility




Figure 5 – SGN underground utility and survey area

Measurements on drains and sewers are to the invert levels.

Measurements on cables and metallic pipes are to the centre of the electromagnetic field.

Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 13 of 16

In general, depths detected using GPR will be to the top of the asset. Depths are affected by geophysical considerations but also user interpretation.

As part of our **'Detection Survey type B'**, passive and active EML sweeps were undertaken across the whole survey area at intervals defined by the required detection method. Any linear feature identified in the data whilst on-site shall be either followed to a node where the identity of the utility can be established or, where this is not practical, labelled as "unknown utility".

Where no utility connected to a utility related topographical feature (e.g. manhole, lamp post etc.) the site team carried out a site check without success. Further investigation ("survey type A") may be required.

Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 14 of 16

5 Additional Information

Please note that the Survey Scope above defines the required and implemented methodology and techniques used on this project. The following information is a brief guide into the survey methods used to undertake a Utility Detection Survey (Survey Type B).

5.1 What is Utility Detection and Mapping?

A utility detection survey provides information on below ground infrastructure such as the position, depth and type of asset. Records are obtained from all asset owners and are used as a basis for the survey and show the infrastructure and its expected position. Each of these assets are searched for using the most appropriate geophysical equipment and the information marked on the surface using temporary spray paint. A majority can be detected using electromagnetic location.

Quite simply, an operative can apply a known frequency to a cable or pipe with metallic composition using a signal generator. This creates an electromagnetic field and is detected using a handheld receiver. The signal can be applied in a variety of ways that may include cover lifting, direct connection or induction methods. The common term for this type of utility detection is EML.

For metallic and non-metallic utilities, Ground Penetrating Radar (GPR) is a common method of detection. An antenna is typically pushed in a trolley configuration with the data viewed on a laptop. The system transmits pulses of high-frequency radio waves into the ground. The transmitted energy is reflected from all buried objects or distinct differences in the earth materials. A reflection known as a radargram can be viewed, from which an operator can distinguish buried assets and mark them on the surface of the ground. Data can also be stored and analysed in an office environment (post-processing) allowing further filtering and production of results. The common term for this type of utility detection is GPR.

GPR can be applied in different ways. In many instances, it is suitable to mark the GPR findings with spray paint on the ground during the survey and record these markings along with the utilities detected using EML techniques. GPR data can also be recorded and processed in an office environment. To acquire this data, either a grid can be marked on the ground for the GPR operator to follow and record these lines or a towable multi-polarised array capable of capturing this grid in one direction using GPS or a Total Station for positioning. The need for recording depends on the site and project needs and the technique used is largely dependent on accessibility and time available.

When using a towed array GPR system, tracking is achieved by using GPS in open areas and total station positioning under tree lined locations or urban corridors. When approaching the GPR survey, coverage and accurate position are the main considerations in terms of data collection. An escort vehicle is used to protect other road users while the GPR antenna is towed within the carriageway and performing the survey. All data is logged and analysed in an office environment using dedicated software.

Many other techniques are used during a Utility Detection Survey to detect utilities. By far the most common techniques are EML and GPR and both should be used to provide the best chance of detecting known and unknown buried assets, this is due to the limitations present in each method. Combining these techniques however, with records and experience can provide invaluable information for the life span of a construction project and the limitations of each detection techniques are balanced.

To preserve the survey and create a map, the detected utility markings and topographic features of the survey area are recorded using geospatial techniques. Total stations, GNSS (Global Navigation Satellite System), Laser scanning and other land surveying principles are used to achieve the result. This information is used to produce drawings in 2D and also 3D models.

Each element of the above can be tailored to meet the project scope.

Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 15 of 16

5.2 What is PAS 128?

PAS 128:2014: Specification for underground utility detection, verification and location.

The purpose of this document is to set out clear provisions to those engaged in the detection, verification and location of active, abandoned, redundant or unknown utilities. With practitioners using this guideline, the aim is to provide clarity in the service and methods employed, consistency, clear classification of results, standardisation of deliverables and accountability.

By following PAS 128, the accuracy, method used and certainty of the results for each utility detection can be clearly communicated.

Catsurveys recommend that this document is consulted in conjunction with all detection surveys provided, as an aid in understanding the survey results and when considering a utility survey and the level of information required.

PAS 128 is available from the British Standards Institution.

5.3 Benefits of a Utility Detection Survey (Survey Type B)

When implemented early in the design phase of a project, this survey can eliminate many costs and delays due to unexpected encounters with underground utilities.

There are many advantages which are obtained from a well-executed detection survey, including:

- Improvements in the safety and wellbeing of the workforce and public
- Risk Management
- Minimise utility damage and associated costs
- Minimise project delays
- Allow for efficient planning and design
- Avoid unnecessary and abortive work
- Non-intrusive survey method

5.4 Limitations of Current Technology

It should be noted, that the current level of existing technology and methodology cannot be guaranteed to detect all utilities below the ground, particularly small diameter pipes or cables at depth and chamber wall thickness. This is true, even when all aspects of a utility survey are conducted in the optimum manner.

There may be utilities present that due to the limitations in current technology or site related factors, may not be evident at the time of the survey. Non-located utilities may not appear on the final survey drawing. The Client is reminded to ensure observance of HSG47 and best practice when excavating. No liabilities for errors, omissions or exceptions can be accepted by Catsurveys Ltd.

6 Accuracy Compliance

6.1 General

We undertake to survey only for declared utilities shown on asset owners drawings. These are supplied by the client or a DURS is agreed to be provided by Catsurveys at the point of order. We will however, endeavour to locate and track any utilities not featured on record drawings but for technical reasons cannot guarantee to do so. Failure to detect or fully track any declared utilities will be recorded in detail. Any utility that may be undetectable would be plotted on our drawing and annotated appropriately, using quality levels in accordance with PAS 128. The DURS document is valid for 3 months.

Survey Report		
Barkham Solar Farm	Ref: 230633	19/12/2023
Underground Utility Detection and Topographical Survey	Version: P01	Page 16 of 16

The survey is based on Ordnance Survey National Grid OSGB36 by GPS OSTN15 transformation. All levels relate to Ordnance Survey datum Newlyn using GPS geoid model OSGM (15).

6.2 Examples of Mains and / or Services that can be detected

- Water pipes of 38mm and above
- Gas pipes of 38mm and above
- Electric supply cables of 230V to 400kV
- Electric cables to street lighting
- Telecommunication cables
- Foul sewers
- Storm sewers
- Combined sewers

Please note that the survey scope defines, which mains (and services) have been recorded on the current project.

6.3 Advisory Note

Whilst every effort has been made to detect all underground utility assets, no detection technique finds every buried utility. For excavation work, assume utilities are present and act accordingly.

6.4 Calibration Procedures and Records

Calibration of all equipment is carried out in line with manufacturers specification.

A calibration procedure is also undertaken on site prior to survey works commencing. A depth to a utility can be verified from an inspection cover and checked using the EML and GPR for comparison. If the depths do not correlate, these instruments will be deemed as unserviceable and sent to the manufacturers for calibration/ repair. Replacement equipment will be then used.

All GPR survey equipment has a calibration procedure when beginning the survey and each time the system is applied to a different ground make-up.

6.5 Horizontal and Vertical Accuracy

Accuracy of underground utilities can vary depending on the type, diameter and material of the utility, its depth and also local soil conditions. Whilst best practice is implemented, errors may occur in relation to the positions given for buried utilities. In certain cases, this error may be in excess of +/- 20% of the value stated.

Accuracy of topographical features are +/- 0.05m.