



Main Roof_Rf-01
Typical Trussed Roof

Wall Tie (*External Walls, Block Inner Leaf*)
Ancon wall tie RT2, or similar approved,
insulation retainer clip. Spaced 450mm
vertically and 750mm horizontally staggered.



All blockwork strengths to be confirmed by Structural engineers.
Wall stability and slenderness ratio to be checked/ confirmed by engineer.
Truss setting out by engineer.

1:10

0.2m 0 0.2m 0.4m 0.6m 0.8m 1m

NOTES
ALL DIMENSIONS MUST BE CHECKED ON SITE AND NOT SCALED
FROM DRAWING. DRAWINGS TO BE READ IN CONJUNCTION
WITH ALL RELEVANT ARCHITECTURAL AND STRUCTURAL
DRAWINGS, SPECIFICATIONS AND CONTRACT DOCUMENTS.
ERRORS AND OMISSIONS TO BE REPORTED TO THE ARCHITECT.
THIS DRAWING IS COPYRIGHT.

SCALE (A1)	1:10	CAD REF	5709-1200	
DATE	Mar 25	DRAWN	VK	
JOB No.	5709	DWG No.	27.01	A

MERIDIAN HOUSE, 2 RUSSELL STREET, WINDSOR
BERKSHIRE, SL4 1HQ
TEL: 01753 857092 FAX: 01753 857096
WEB: www.edgingtons.co.uk EMAIL: mail@edgingtons.co.uk