

3rd Party Planning Application – 242098

External Email

CAUTION: This is an EXTERNAL EMAIL - STOP & THINK before clicking a link or opening attachments.

Wokingham District Council

Our DTS Ref: 77637

P.O Box 157

Your Ref: 242098

Shute End

WOKINGHAM

Berks

RG40 1WR

3 September 2024

Dear Sir/Madam

Re: PINWOOD CAMPUS , NINE MILE RIDE, WOKINGHAM, RG40 3EW

Waste Comments

.

With the information provided, Thames Water has been unable to determine the Foul water infrastructure needs of this application. Thames Water has contacted the developer in an attempt to obtain this information and agree a position for FOUL WATER drainage, but have been unable to do so in the time available and as such, Thames Water request that the following condition be added to any planning permission. “No development shall be occupied until confirmation has been provided that either:- 1.

Foul water Capacity exists off site to serve the development, or 2. A development and infrastructure phasing plan has been agreed with the Local Authority in consultation with Thames Water. Where a development and infrastructure phasing plan is agreed, no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan, or 3. All Foul water network upgrades required to accommodate the additional flows from the development have been completed. Reason - Network reinforcement works may be required to accommodate the proposed development. Any reinforcement works identified will be necessary in order to avoid sewage flooding and/or potential pollution incidents. The developer can request information to support the discharge of this condition by visiting the Thames Water website at thameswater.co.uk/preplanning. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (e-mail: devcon.team@thameswater.co.uk) prior to the planning application approval.

With the information provided Thames Water has been unable to determine the waste water infrastructure needs of this application. Thames Water has contacted the developer in an attempt to obtain this information and agree a position for SURFACE WATER drainage, but have been unable to do so in the time available and as such Thames Water request that the following condition be added to any planning permission. “No development shall be occupied until confirmation has been provided that either:- 1. Surface water capacity exists off site to serve the development or 2. A development and infrastructure phasing plan has been agreed with the Local Authority in consultation with Thames Water. Where a development and infrastructure phasing plan is agreed, no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan. Or 3. All Surface water network upgrades required to accommodate the additional flows from the development have been completed. Reason - Network reinforcement works may be required to accommodate the proposed development. Any reinforcement works identified will be necessary in order to avoid flooding and/or potential pollution incidents. The developer can request information to support the discharge of this condition by visiting the Thames Water website at thameswater.co.uk/preplanning. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (e-mail: devcon.team@thameswater.co.uk) prior to the planning application approval.

Water Comments

With regard to water supply, this comes within the area covered by the South East Water Company. For your information the address to write to is - South East Water Company, Rocfort Road, Snodland, Kent, ME6 5AH, Tel: 01444-448200

Supplementary Comments

Thames Water advise that a drainage strategy should contain the points of connection to the public sewerage system as well as the anticipated flows (including flow calculation method) into the proposed connection points. This data can then be used to determine the impact of the proposed development on the existing sewer system. If the drainage strategy is not acceptable Thames Water will request that an impact study be undertaken.

Yours faithfully

Development Planning Department

Development Planning,

Thames Water,

Maple Lodge STW,

Denham Way,

Rickmansworth,

WD3 9SQ

[Tel:020 3577 9998](tel:02035779998)

Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk Visit us online

<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.thameswater.co.uk%2F&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7Cbe1e6c9a6960434f547608dccbea0257%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638609453151100900%7CUnknown%7CTWFpbGZsb3d8eyJWljiMC4wLjAwMDAiLCJQIjoiV2luMzliLCJBTiI6Ikl1haWwiLCJXVCi6Mn0%3D%7C0%7C%7C%7C&sdata=JHCSZiadyMEM9olBroFOqqwTp3%2FRiq4jz9hPGEKx%2FgY%3D&reserved=0> , follow us on twitter

<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.twitter.com%2Fthameswater&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7Cbe1e6c9a6960434f547608dccbea0257%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638609453151113552%7CUnknown%7CTWFpbGZsb3d8eyJWljiMC4wLjAwMDAiLCJQIjoiV2luMzliLCJBTiI6Ikl1haWwiLCJXVCi6Mn0%3D%7C0%7C%7C%7C&sdata=3XpbFY8LH72nimc6Bo%2B%2BmrUshRTXN2%2FyHBFMfxYXSqk%3D&reserved=0>

or find us on

<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.facebook.com%2Fthameswater&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7Cbe1e6c9a6960434f547608dccbea0257%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638609453151122279%7CUnknown%7CTWFpbGZsb3d8eyJWljiMC4wLjAwMDAiLCJQIjoiV2luMzliLCJBTiI6Ikl1haWwiLCJXVCi6Mn0%3D%7C0%7C%7C%7C&sdata=kBv7pGWO%2FsqrAgsp7%2Fbea%2FIpj60PTLApWPZxqsJtfpY%3D&reserved=0>

We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.