

3rd Party Planning Application – 242193

External Email

CAUTION: This is an EXTERNAL EMAIL - STOP & THINK before clicking a link or opening attachments.

Wokingham District Council

Our DTS Ref: 77696

P.O Box 157

Your Ref: 242193

Shute End

WOKINGHAM

Berks

RG40 1WR

3 September 2024

Dear Sir/Madam

Re: GLASSPOOL FARM, PART LANE, RISELEY, READING, BERKSHIRE, RG7 1RU

Waste Comments

With regard to SURFACE WATER drainage, Thames Water would advise that if the developer follows the sequential approach to the disposal of surface water we would have no objection. Management of surface water from new developments should follow guidance under sections 167, 168 & 169 in the National Planning Policy Framework. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. Should you require further information please refer to our website.

<https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fhelp%2Fhome-improvements%2Fhow-to-connect-to-a-sewer%2Fsewer->

[connection-](#)

[design&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7C49c311bece224a40c30208dccbedc578%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638609469317986220%7CUnknown%7CTWFpbGZsb3d8eyJWlloiMC4wLjAwMDAiLCJQljoiv2luMzliLCJBTiI6Ikl1haWwiLCJXVCi6Mn0%3D%7C0%7C%7C%7C&sdata=1JQfsQPmB3Gfy5bQu2R8F2dzimps6AU0v6MG7ZdDrQs%3D&reserved=0](#)

.

Thames Water would advise that with regard to WASTE WATER NETWORK and SEWAGE TREATMENT WORKS infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

Water Comments

If you are planning on using mains water for construction purposes, it's important you let Thames Water know before you start using it, to avoid potential fines for improper usage. More information and how to apply can be found online at thameswater.co.uk/buildingwater.

On the basis of information provided, Thames Water would advise that with regard to water network and water treatment infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommends the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Yours faithfully

Development Planning Department

Development Planning,

Thames Water,

Maple Lodge STW,

Denham Way,

Rickmansworth,

WD3 9SQ

[Tel:020 3577 9998](tel:02035779998)

Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk Visit us online

<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.thameswater.co.uk%2F&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7C49c311bece224a40c30208dccbedc578%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638609469317997209%7CUnknown%7CTWFpbGZsb3d8eyJWlloiMC4wLjAwMDAiLCJQIjoiV2luMzliLCJBTil6lk1haWwiLCJXVCi6Mn0%3D%7C0%7C%7C%7C&sdata=ml1%2ByocTWOLqIGhxBX6YRjX4ro%2BpSIPoq4FIYfB88M8%3D&reserved=0> , follow us on twitter

<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.twitter.com%2Fthameswater&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7C49c311bece224a40c30208dccbedc578%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638609469318004448%7CUnknown%7CTWFpbGZsb3d8eyJWlloiMC4wLjAwMDAiLCJQIjoiV2luMzliLCJBTil6lk1haWwiLCJXVCi6Mn0%3D%7C0%7C%7C%7C&sdata=y3HrQQB1aQA3UfKwjtNWAeeNus6MWjlgOst8JleilFU%3D&reserved=0> or find us on <https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.facebook.com%2Fthameswater&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7C49c311bece224a40c30208dccbedc578%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638609469318009346%7CUnknown%7CTWFpbGZsb3d8eyJWlloiMC4wLjAwMDAiLCJQIjoiV2luMzliLCJBTil6lk1haWwiLCJXVCi6Mn0%3D%7C0%7C%7C%7C&sdata=N8SWnM327OeDZDxYj0vQ%2BIX972BHBDDZg2FUT1Y7al4%3D&reserved=0>.

We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.