

DELEGATED OFFICER REPORT



WOKINGHAM
BOROUGH COUNCIL

Application Number:	251522
Site Address:	96 Mccarthy Way, Finchampstead, Wokingham, RG40 4UB
Expiry Date:	19 August 2025
Site Visit Date:	Not required unless objection received
Proposal: Application for the prior approval of the erection of a single storey rear extension, which would extend beyond the rear wall of the original house by 4.0m, for which the maximum height would be 3.9m and the height of the eaves 3.0m.	

PLANNING HISTORY

Application No.	Description	Decision & Date
1332/71	Outline	Approved: 16/03/1972
935/72	58 detached houses and 60 terrace houses	Approved: 08/06/1972
251149	Application for the prior approval of the erection of a single storey rear extension, which would extend beyond the rear wall of the original house by 4.0m, for which the maximum height would be 3.9m and the height of the eaves 3.3m.	Refused: 17/06/2025

REPRESENTATIONS

Neighbours	None received
------------	---------------

APPRAISAL

Site Description: Two storey detached dwelling.

Land/ Property Designations:

- There are no listed buildings at the site and the property is not within a Conservation Area or other 'Article 2(3) land' (Town and Country Planning (General Permitted Development) Order 2015).
- The site is not subject to any wildlife or habitat designations.
- The site is situated within a modest development location of Finchampstead.

Consultation: All adjoining neighbouring properties were consulted on 11 July 2025 and given the statutory 21 days to respond. No objections have been received.

			Yes	No
s.55	1	Does it constitute development?	✓	
s.191	2	Would it be contrary to an enforcement notice?		✓
s.187a Art.3 (4)	3	Would it be contrary to any condition imposed by any planning permission granted or deemed to be granted?		✓
Art.3 (5)	4	Are the building operations involved in the construction of the original building lawful?	✓	
Art.3 (6)	5	Does it involve the formation, laying out or material widening of a means of access to an existing highway which is a trunk or classified road, or creates an obstruction to the view of persons using any highway used by vehicular traffic, so as to be likely to cause danger to such persons?		✓
Art.4	6	Is there an 'Article 4 Direction' in effect for the site?		✓
Sch.2 Pt. 1 A	7	Does it consist of enlargement, improvement or other alteration of a dwellinghouse?	✓	
A.1(a)	8	Has permission to use the dwellinghouse as a dwellinghouse been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule (changes of use)?		✓
A.1(b)	9	Would the total area of ground covered by buildings (other than the original dwelling) exceed 50% of the total area of the curtilage?		✓
A.1(c)	10	Would the height of the part of the dwellinghouse enlarged, improved or altered exceed the height of the highest part of the roof of the existing dwellinghouse?		✓
A.1(d)	11	Would the height of the eaves of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the existing dwellinghouse?		✓
A.1(e)	12	Would the enlarged part of the dwellinghouse extend beyond a wall which - (i) fronts the principal elevation of the original house; or (ii) fronts a highway and forms a side elevation of the original dwellinghouse?		✓
A.1(f)	13	If the enlarged part of the dwellinghouse is single storey, would it either: (i) extend beyond the rear wall of the original dwellinghouse by more than: 4 metres in the case of a detached dwellinghouse 3 metres in the case of any other dwellinghouse; or (ii) exceed 4 metres in height		✓
A.1(g)	14	For a dwellinghouse not in article 2 (3) land (incl conservation area) if the enlarged part of the dwellinghouse is single-storey, would it either (i) extend beyond the rear wall of the original dwellinghouse by more than: 8 metres in the case of a detached dwellinghouse 6 metres in the case of any other dwellinghouse; or		✓

		(ii) exceed 4 metres in height		
		NB: As per Para A.4 of Part 1 of for development that exceeds the limits in para A.1 (f) (question 13) but is allowed by para A.1 (g) (question 14) <u>Prior Approval via the 'Neighbours Notification Scheme' is required</u>		
A.1(h)	15	If the extension would be more than a single storey would it: (i) extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or (ii) be within 7 metres of the rear boundary of the curtilage.	N/A	N/A
A.1(i)	16	Would the enlarged part of the dwellinghouse would be within 2 metres of the boundary with an eaves height in excess of 3 metres?		✓
A.1(j)	17	Would the enlarged part of the dwellinghouse extend beyond a wall forming a side elevation of the original dwellinghouse and: (i) exceed 4 metres in height, (ii) have more than a single storey, or (ii) have a width greater than half the width of the original dwellinghouse		✓
A.1(k)	18	Would the development consist of or include: (i) the construction or provision of a verandah, balcony or raised platform, (ii) the installation, alteration or replacement of a microwave antenna, (iii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or (iv) an alteration to any part of the roof of the dwellinghouse.		✓
A.2(a)	19	Article 2(3) land (inc. conservation areas): a. Would the development consist of or include the cladding of any part of the exterior of the dwellinghouse with stone, artificial stone, pebble dash, render, timber, plastic or tiles?	N/A	N/A
A.2(b)	20	b. Would the extension extend beyond a wall forming a side elevation of the original dwellinghouse?	N/A	N/A
A.2(c)	21	c. Would the extension have more than a single storey and extend beyond the rear wall of the original dwellinghouse?	N/A	N/A
	22	Would it affect or be within the Root Protection Area of a TPO'd tree? <i>* Does not affect Article 3 permission but separate TPO approval will likely be needed.</i>		✓

Conclusion: Prior approval for the proposed single storey rear extension is available under Article 3 of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended). As no objections have been received as a result of the Neighbour Consultation Scheme, the prior approval of the Local Planning Authority is not required in this instance.

The Public Sector Equality Duty (Equality Act 2010): In determining this application the Council is required to have due regard to its obligations under the Equality Act 2010. The key equalities protected characteristics include age, disability, gender, gender reassignment, marriage and civil partnership, pregnancy and maternity, race,

religion or belief. There is no indication or evidence (including from consultation on the application) that persons with protected characteristics as identified by the Act have or will have different needs, experiences, issues and priorities in relation to this particular planning application and there would be no significant adverse impacts as a result of the development.

RECOMMENDATION	
Recommendation:	Prior approval not required
Date:	14 August 2025
Earliest date for decision:	1 August 2025

Recommendation agreed by: (Authorised Officer)	
Date:	14 August 2025