

BURIED UTILITIES RISK NOTE	
• Buried utilities are present on and in the vicinity of the site.	
• The Contractor must satisfy themselves that they have seen utility returns for the area and that appropriate Risk Assessment Method Statement (RAMS) are in place and implemented to ensure that buried and/or overhead services are located prior to any works taking place.	
• Any RAMS shall address safe procedures for protection and working in the proximity of services.	
DESIGNERS CDM NOTE - RESIDUAL RISKS IDENTIFIED	
The design Engineer(s) have analysed this design as the scheme has been developed, in order to identify if there are any significant residual risk hazards (i.e. unusual, unexpected, abnormal or difficult).	
Residual risks HAVE been identified and are therefore shown on this drawing. These risks have not been possible to remove by design.	
This statement assumes that a competent Contractor with the appropriate qualified staff will be employed for the works, and that they will be familiar with site wide construction risks and hazards that they can reasonably be expected to encounter as part of their work.	

DESIGNER NOTE
Surface Water system designed for a 1 in 100 year event plus an allowance of 40% for climate change.
Soakage testing to BRE365 carried out on site, abandoned due to low infiltration.
Groundwater found at 1.8m below ground level in January 2025

CDM RESIDUAL RISK ITEM	
Existing services likely within working area.	
Danger to site personnel and general public	
CDM RESIDUAL RISK ITEM	
Drainage pipes, manhole rings covers and fittings.	
Risk of Manual handling injury.	
CDM RESIDUAL RISK ITEM	
Contact with waste water when making drainage connections.	
Risk of infection from Weils disease etc.	
CDM RESIDUAL RISK ITEM	
Above Ground activities.	
Possibility of objects falling from operations at high level onto persons working or passing below.	

Package Treatment Plant (Klargester IPS BioAir 2)
With integrated pump
Population Equivalent (PE) = 4P Assumed
Standard Loading = 150l / head / day
BOD Loading = 60g / head / day
Ammonia as N Loading = 8 / head / day

Pumping station control kiosk with visible alarm. Electricity supply required

Surface Water Network					
Manhole Reference	Invert Level (m)	Cover Level (m)	Depth (m)	Chamber Details	Cover Loading
C1	51.000	-	-	Headwall	-
C2	51.020	51.55	0.53	PPIC Ø450	D400
S1	51.033	51.60	0.57	Flow Control	D400
S2	51.117	51.60	0.48	PPIC Ø450	A15
S3	51.197	51.60	0.40	Rod. Eye	A15
S1	51.033	51.60	0.57	Flow Control	D400
S1.1	51.171	51.60	0.43	Rod. Eye	D400

Manhole Reference	Invert Level (m)	Cover Level (m)	Depth (m)	Chamber Details	Cover Loading
C2	51.020	51.55	0.53	PPIC Ø450	D400
F1	50.850	51.60	0.75	Special	A15
F2	50.931	51.55	0.62	PPIC Ø450	A15
F3	51.000	51.55	0.55	MAC Ø300	A15

