

PLANNING REF : 250321
PROPERTY ADDRESS : 32 Easby Way
: Lower Earley, Reading
: RG6 3XA
SUBMITTED BY : Mr William Luck
DATE SUBMITTED : 22/02/2025

COMMENTS:

Can the applicant confirm that the linear drain across the front of the drive continues for the FULL frontage covered by the application, to prevent any run-off onto the highway? As drawn, water can bypass the linear drain at each end and discharge onto the highway. Can the applicant provide details of the soakaway serving the linear drain and identify its location on site?