

MEMORANDUM

From:	Built Heritage Officer	Service:	Green Infrastructure
--------------	------------------------	-----------------	----------------------

Application No.	243063	Site Visit Made:	Yes
------------------------	--------	-------------------------	-----

Address:	Albany House, 14 Shute End, Wokingham.
-----------------	--

Proposal:	Application for submission of details to comply with the following conditions of planning consent 242567 dated 02.12.2024. Condition 4 relates to lime mortar details.
Relevant built heritage condition text.	Condition 4 of LBC 242567. Lime Mortar Details - Notwithstanding the details submitted, prior to undertaking the rebuilding of the brick boundary walls, details, and samples of lime mortar to be used shall be submitted to and approved in writing by the local planning authority. Works to reconstruct the section of the brick boundary wall shall then be undertaken in accordance with the details as approved.


Summary Of Recommendations

Condition 4 of LBC 242567 be **discharged in full**.

Comments

The sample of the 3:1 ration building sand to hydrylic lime 50 mortar to be used to rebuild the curtilage listed brick boundary wall to the rear of Albany House is considered acceptable mortar mix.

Date:	13/01/25	Signed:	Keith Frost Built Heritage Officer
--------------	----------	----------------	---------------------------------------



Sample from pot, still damp.



Dried out sample.