

Date: 5 September 2024
Application: 242195



**WOKINGHAM
BOROUGH COUNCIL**

WBC Highways

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Highways,

Householder Consultation

Application Number: 242195

Applicant: Tom and Emily Plews

Site Address: 8 South Drive, Wokingham, RG40 2DH

Parish: Wokingham Town

Grid Reference: Easting - 481455, Northing - 168028

Type of Development: Other Householder

Proposal: Householder application for the proposed single storey extension to facilitate leisure facilities followed by the erection of a detached garage.

Case Officer: Claire Moore

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 242195. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	JP		
Service	WBC Highways	App No:	242195
Address:	8 South Drive, Wokingham, RG40 2DH.		
Proposal:	Householder application for the proposed single storey extension to facilitate leisure facilities followed by the erection of a detached garage.		
Type of Development:	Other Householder		
Site Visit Made:	Yes/No		

Summary Of Recommendations

- ☐ No comment
- ☒ No objection
- ☐ No objection subject to conditions (and reasons) **stated below**
- ☐ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

While the total numbers of habitable rooms cannot be identified from the application, the applicant proposes extension to include a swimming pool and provisions of a garage of internal dimensions 6.3m x 10.4m, resulting in an increase of 1 allocated parking space. Three driveway parking spaces are also indicated on the site plan.

According to the WBC Car Parking Standards, the development in Urban location will generally require two to three parking within the red line boundary. Each parking space shall have minimum dimensions of 5.0m x 2.5m.

The site has ample spaces for more than the four proposed provisions, which is acceptable.

Conditions & Reasons (if required)

Date:	6/9/2024	Signed:	JP
--------------	----------	----------------	----