

Date: 9 October 2025
Application: 251770



**WOKINGHAM
BOROUGH COUNCIL**

WBC Highways

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Highways,

Householder Consultation

Application Number: 251770

Applicant: Mr Umar Gill

Site Address: 230 Hyde End Road, Spencers Wood, Wokingham, RG7 1DG

Parish: Shinfield

Grid Reference: Easting - 472208, Northing - 166615

Type of Development: Other Householder

Proposal: Householder application for the proposed erection of a single storey front extension with pitched roof and open canopy overhang, alterations to front fenestration including window repositioning, erection of a single storey rear extension with roof light, alongside the enlargement of the driveway, and demolition of the existing rear conservatory.

Case Officer: Tariq Bailey-Biggs

Development Management has received the above application, and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 251770. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be requested from the case officer.

Your observations are required in respect of this application by **30 October 2025**.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	Stantec LS		
Service	WBC Highways	App No:	251770
Address:	230 Hyde End Road, Spencers Wood, Wokingham, RG7 1DG.		
Proposal:	Householder application for the proposed erection of a single storey front extension with pitched roof and open canopy overhang, alterations to front fenestration including window repositioning, erection of a single storey rear extension with roof light, alongside the enlargement of the driveway, and demolition of the existing rear conservatory.		
Type of Development:	Other Householder		
Site Visit Made:	Yes/No		

Summary Of Recommendations

- ☐ No comment
☒ No objection
☐ No objection subject to conditions (and reasons) **stated below**
☐ Request further information before determination as **stated below**
☐ Objection due to the reason(s) **stated below**

Comments On Proposal

No increase in the number of habitable rooms is proposed. Drawing P-003 indicates the existing parking spaces are to be maintained. Highways have no concerns regarding the proposed development.

Conditions & Reasons (if required)

Date:	16.10.25	Signed:	Stantec LS
--------------	----------	----------------	------------