

3rd Party Planning Application – 250267

Wokingham District Council

Our DTS Ref: 78697

P.O Box 157

Your Ref: 250267

Shute End

WOKINGHAM

Berks

RG40 1WR

12 March 2025

Dear Sir/Madam

Re: 31, BARKHAM RIDE, FINCHAMPSTEAD, WOKINGHAM, RG40 4EX

Waste Comments

Thames Water would advise that with regard to FOUL WATER sewerage network infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

The application indicates that SURFACE WATER will NOT be discharged to the public network and as such Thames Water has no objection, however approval should be sought from the Lead Local Flood Authority. Should the applicant subsequently seek a connection to discharge surface water into the public network in the future then we would consider this to be a material change to the proposal, which would require an amendment to the application at which point we would need to review our position.

Following initial investigations, Thames Water has identified an inability of the existing SEWAGE TREATMENT WORKS infrastructure to accommodate the needs of this development proposal. As such Thames Water request the following condition be added to any planning permission. "No development shall be occupied until confirmation has been provided that either:- all sewage works

upgrades required to accommodate the additional flows from the development have been completed; or - a development and infrastructure phasing plan has been agreed with the Local Authority in consultation with Thames Water to allow development to be occupied. Where a development and infrastructure phasing plan is agreed no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan. Reason - Sewage Treatment Upgrades are likely to be required to accommodate the proposed development. Any upgrade works identified will be necessary in order to avoid sewage flooding and/or potential pollution incidents." The developer can request information to support the discharge of this condition by visiting the Thames Water website at Development Planning Department (telephone 0203 577 9998) prior to the planning application approval. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (e-mail: devcon.team@thameswater.co.uk) prior to the planning application approval.

Water Comments

If you are planning on using mains water for construction purposes, it's important you let Thames Water know before you start using it, to avoid potential fines for improper usage. More information and how to apply can be found online at thameswater.co.uk/buildingwater.

On the basis of information provided, Thames Water would advise that with regard to water network and water treatment infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommends the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Supplementary Comments

An upgrade is planned for Arborfield STW. This will improve its ability to treat the volumes of incoming sewage, reducing the need for untreated discharges in wet weather. The scheme is due to complete in 2028.

Yours faithfully

Development Planning Department

Development Planning,

Thames Water,

Maple Lodge STW,

Denham Way,

Rickmansworth,

WD3 9SQ

[Tel:020 3577 9998](tel:02035779998)

Email: devcon.team@thameswater.co.uk