

Emy Circuit

From: John Neville [REDACTED]
Sent: 08 September 2026 12:49
To: Emy Circuit
Cc: Gary Du Preez; Josh Hall (Technical); d.sharp
Subject: RE: DoC 261450 Lighting of parking courts and shared surfaces in South Wokingham, phase 2b, parcel R11

Hi Emy,

Please see below feedback from our lighting engineer:

“The colour temperature specified at Wokingham is 3000K which is generally referred to as warm-white light. It sits on the warm side of the colour spectrum. On previous schemes 3000K lanterns have been acceptable for a warm light for ecology reasons.”

Do you need this annotated on the plan or is the above wording sufficient?

Kind regards,

John Neville MRTPI MSc
Planning Manager

Mob: [REDACTED]

Vistry Southern
Central 40 | Lime Tree Way | Chineham Park
Basingstoke | RG24 8GU

Vistry

 **Bovis Homes**
Est. 1885

Linden Homes

 **COUNTRYSIDE Homes**

Countryside Partnerships



Supporting **Crisis** as our charity partner for 2026
Working together to end homelessness

This email is confidential and may be legally privileged. If you are not the intended recipient of this email and its attachments you must not copy, distribute, disclose or use them for any purpose. If you have received this email in error, please notify postmaster@vistrygroup.co.uk and delete all copies from your system. Email communications cannot be guaranteed to be secure or free from error or viruses. Vistry Group accepts no liability for any loss or damage which may be caused by viruses. Opinions, conclusions and other information within this email unrelated to the business of Vistry Group are the responsibility of the individual sender. Vistry Group PLC is registered in England and Wales with registered number 306718. The registered office is 11 Tower View, Kings Hill, West Malling, Kent, ME19 4UY. You can view a copy of our privacy policy: <https://www.vistrygroup.co.uk/site-services/privacy/>.