

Date: 21 August 2024
Application: 242067



WOKINGHAM
BOROUGH COUNCIL

WBC Environmental Health

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Environmental Health,

Outline Planning Approval Consultation

Application Number: 242067

Applicant: The Owner and/or Occupier

Site Address: Land Between Lodge Road And Tape Lane, Hurst, RG10 0EG

Parish: St. Nicholas Hurst

Grid Reference: Easting - 479479, Northing - 173716

Type of Development: Major Dwellings (10+)

Proposal: Outline application for the proposed erection of up to 99 no. dwellings, green infrastructure, open space, pedestrian and cycle links, recreational facilities and other associated infrastructure and access points on Lodge Road and Tape Lane with required improvements. (All matters reserved except for means of access.)

Case Officer: Mark Croucher

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 242067. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	Chris Christofis Env Protection Officer		
Service	WBC Environmental Health	App No:	242067
Address:	Land Between Lodge Road And Tape Lane, Hurst, RG10 0EG.		
Proposal:	Outline application for the proposed erection of up to 99 no. dwellings, green infrastructure, open space, pedestrian and cycle links, recreational facilities and other associated infrastructure and access points on Lodge Road and Tape Lane with required improvements. (All matters reserved except for means of access.)		
Type of Development:	Major Dwellings (10+)		
Site Visit Made:	No		

Summary Of Recommendations

- ☐ No comment
- ☐ No objection
- ☒ No objection subject to conditions (and reasons) **stated below**
- ☐ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

In reviewing this application from an environmental health perspective, my role as a consultee is to support planning by being considerate of issues relating to public health and the environment and if any environmental health factor will adversely affect future occupants of the proposed site or nearby properties.

My comments are from an environmental health perspective only, other planning matters are within the remit of planning officers.

This a relatively large-scale development, the number of proposed dwellings has been reduced since a previous application under reference 220458, this app is now for up to 99 dwellings.

The site is adjacent to Whistely court and lea farm filled ground, on Whistley Mill Lane, Hurst, first filled in 1988 with commercial/industrial and household waste, this former landfill sites gas consultation zone encompasses part of the proposed development site.

Previous application for the site under reference 220458 the EA raised an objection due to a limited flood risk assessment; this will need to be addressed in this revised application.

Hydrocks initial ground site investigation is included in the supporting documents in 5 parts and goes a some way to meeting the condition as we would apply it (outline below) .

I have included a condition recommendation relating to external plant noise as ASHP have become more popular, in the event of a large scale roll out of ASHP, a noise assessment would be required to inform the design and installation to achieve the condition, if there is no external plant in the final design schematic this will not be required.

The conditions I would recommend are listed below.

Conditions & Reasons (if required)

Site Characterisation/Land Contamination Investigation.

An investigation and risk assessment should be completed in accordance with a scheme to assess the nature and extent of any contamination on the site, including radon gas, (whether it originates on the site or not). The investigation and risk assessment should be undertaken by competent persons and a written report of the findings produced. The written report would be subject to the approval in writing of the Local Planning Authority. The report of the findings should include:

(i) a survey of the extent, scale, and nature of any contamination.

(ii) an assessment of the potential risks to:

- human health,
- property (existing or proposed) including buildings, crops, livestock, pets, woodland and service lines and pipes,
- adjoining land,
- groundwaters and surface waters,
- ecological systems,
- archaeological sites and ancient monuments.

(iii) an appraisal of remedial options, and proposal of the preferred option(s).

This must be conducted in accordance with DEFRA and the Environment Agency's 'Model Procedures for the Management of Land Contamination, CLR 11'.

Submission of Remediation Scheme (where required).

A detailed remediation scheme to bring the site to a condition suitable for the intended use by removing unacceptable risks to human health, buildings and other property and the natural and historical environment should be prepared and would be subject to the approval in writing of the Local Planning Authority. The scheme should include all works to be undertaken, proposed remediation objectives and remediation criteria, timetable of works and site management procedures. The scheme should ensure that the site will not qualify as contaminated land under Part 2A of the Environmental Protection Act 1990 in relation to the intended use of the land after remediation.

Unexpected Land Contamination.

If land contamination is found at any time during site clearance, groundwork, and construction the discovery shall be reported as soon as possible to the local planning authority. A full contamination risk assessment shall be carried out and if found to be necessary, a 'remediation method statement' shall be submitted to the local planning authority for written approval.

Reason - To ensure that any contamination of the site is identified at the outset to allow remediation to protect existing/proposed occupants of property on the site and/or adjacent land. Relevant policy: NPPF Section 15 (Conserving and Enhancing the Natural Environment) and Core Strategy policies CP1 & CP3.

Construction Method Statement (Management Plan).

No development shall take place, including any works of demolition, until a Construction

Method Statement/plan has been submitted to, and approved in writing by, the local planning authority. The approved statement/plan shall be adhered to throughout the construction period. The Statement shall provide for:

- the parking of vehicles of site operatives and visitors.
- loading and unloading of plant and materials (including times, these should be in line with permitted hours of work).
- storage of plant and materials used in constructing of the development.
- the erection and maintenance of security hoarding including decorative displays and facilities for public viewing, (where appropriate).
- wheel washing facilities and an area cleaning regime.
- measures to control the emission of noise, dust, and dirt during construction,
- method of recycling/disposing of waste resulting from demolition and construction works.
- Details of pest control measures if required.
- asbestos survey results and if present a safe removal and disposal plan to be submitted.

Reason - In the interests of highway safety & convenience and neighbour amenities.
Relevant policy: Core Strategy policies CP3 & CP6.

Hours of work

No work relating to the development hereby approved, including works of demolition or preparation prior to building operations, shall take place other than between the hours of 08:00 and 18:00 Monday to Friday and 08:00 to 13:00 Saturdays and at no time on Sundays or Bank or National Holidays.

Reason - to protect the occupiers of neighbouring properties from noise and disturbance outside the permitted hours during the construction period. Relevant policy: Core Strategy policies CP1 and CP3 and Managing Development Delivery Local Plan policy CC06

Plant/Machinery to be attenuated.

All plant, machinery and equipment installed or operated in connection with the conducting of this permission shall be located, enclosed or attenuated so that noise therefrom does not exceed at any time a level of 5dB[A] below the existing background noise when measured at a point one metre external to the nearest residential or noise sensitive property.

Any recommended noise mitigation measures should be retained and maintained thereafter.

Reason - To ensure that no nuisance or disturbance is caused to the occupiers of properties. Relevant policy: NPPF Section 15 (Conserving and Enhancing the Natural Environment), Core Strategy policies CP1 and CP3 and Managing Development Delivery Local Plan policy CC06.

Date:	02/10/2024	Signed:	C Christofis
--------------	------------	----------------	--------------