

Date: 18 November 2024
Application: 242858



**WOKINGHAM
BOROUGH COUNCIL**

WBC Drainage

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Drainage,

Full Planning Approval Consultation

Application Number: 242858

Applicant: Mr D Fail

Site Address: 106 Ellis Road, Crowthorne, Wokingham, RG45 6PH

Parish: Wokingham Without

Grid Reference: Easting - 483523, Northing - 164664

Type of Development: Minor All other developments

Proposal: Full application for the proposed erection of 1no. four bedroom dwelling, following the demolition of existing garage, plus new dropped kerb.

Case Officer: Rowan Reynolds

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 242858. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	Boniface Ngu Flood Risk & Drainage		
Service	WBC Drainage	App No:	242858
Address:	106 Ellis Road, Crowthorne, Wokingham, RG45 6PH.		
Proposal:	Full application for the proposed erection of 1no. four bedroom dwelling, following the demolition of existing garage, plus new dropped kerb.		
Type of Development:	Minor All other developments		
Site Visit Made:	No		

Summary Of Recommendations

- ☐ No comment
- ☐ No objection
- ☒ No objection subject to conditions (and reasons) **stated below**
- ☐ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

The site is within flood zone 1 but in an area that experiences surface water flooding for the low-risk event.

The **application form** states that surface water runoff will be managed via soakaway while foul will discharge into an existing foul sewer.

We would have no objection to the principle of the development, as represented by **plans and elevation drawing 20-067 01 C dated 09/04/2021** but as drainage details have not been provided, we would **recommend the condition below**:

Conditions & Reasons (if required)

No development shall take place until full details of the drainage system for the site have been submitted to and approved in writing by the LPA. The details shall include:

1. BRE 365 test results demonstrating that infiltration is achievable.
2. Full calculations demonstrating the performance of soakaways.
3. A description of how the proposed development will deal with surface water overland flows.
4. Groundwater monitoring confirming seasonal high groundwater levels in the area.

5. A drainage strategy plan indicating the location and sizing of SuDS features, with the base of any SuDS features located at least 1m above the seasonal high water table level.
6. Details demonstrating how any SuDS for this development would be managed throughout the lifespan of the development and who will be responsible for maintenance.

The approved scheme shall be implemented prior to the first occupation of the development and shall be maintained in the approved form for as long as the development remains on the site.

This is to prevent increased flood risk from surface water run-off. Relevant policy: NPPF (2023) Section 14 (Meeting the Challenge of Climate Change, Flooding and Coastal Change), Core Strategy policy CP1 and Managing Development Delivery Local Plan policies CC09 and CC10.

Date:	18/11/2024	Signed:	Boniface Ngu
--------------	------------	----------------	--------------