

3rd Party Planning Application – 250415

Wokingham District Council

Our DTS Ref: 78687

P.O Box 157

Your Ref: 250415

Shute End

WOKINGHAM

Berks

RG40 1WR

10 March 2025

Dear Sir/Madam

Re: SHINFIELD PARK , WHITLEY WOOD LANE, SHINFIELD, WOKINGHAM, RG2 9FW

Waste Comments

There are public sewers crossing or close to your development. If you're planning significant work near our sewers, it's important that you minimize the risk of damage. We'll need to check that your development doesn't limit repair or maintenance activities, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes.

<https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fdevelopers%2Flarger-scale-developments%2Fplanning-your-development%2Fworking-near-our-pipes&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7Ce48155fc10374b112e7208dd5ff5c1c6%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638772231328000363%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiIlwLjAuMDAwMCIsIlAiOiJXaW4zMilskFOIjoiTWFpbGlldUIjoyfQ%3D%3D%7C0%7C%7C%7C&sdata=BciAPLzWrtTBrrTE21N5%2BveYDErykAON6JxYiX8IPIY%3D&reserved=0>

Thames Water recognises this catchment is subject to high infiltration flows during certain groundwater conditions. The scale of the proposed development doesn't materially affect the sewer network and as such we have no objection, however care needs to be taken when designing new

networks to ensure they don't surcharge and cause flooding. In the longer term Thames Water, along with other partners, are working on a strategy to reduce groundwater entering the sewer networks.

Thames Water recognises this catchment is subject to high infiltration flows during certain groundwater conditions. The developer should liaise with the LLFA to agree an appropriate sustainable surface water strategy following the sequential approach before considering connection to the public sewer network. The scale of the proposed development doesn't materially affect the sewer network and as such we have no objection, however care needs to be taken when designing new networks to ensure they don't surcharge and cause flooding. In the longer term Thames Water, along with other partners, are working on a strategy to reduce groundwater entering the sewer network.

Thames Water would advise that with regard to FOUL WATER sewerage network infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

The application indicates that SURFACE WATER will NOT be discharged to the public network and as such Thames Water has no objection, however approval should be sought from the Lead Local Flood Authority. Should the applicant subsequently seek a connection to discharge surface water into the public network in the future then we would consider this to be a material change to the proposal, which would require an amendment to the application at which point we would need to review our position.

Thames Water would recommend that petrol / oil interceptors be fitted in all car parking/washing/repair facilities. Failure to enforce the effective use of petrol / oil interceptors could result in oil-polluted discharges entering local watercourses.

Water Comments

On the basis of information provided, Thames Water would advise that with regard to water network infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommend the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

There are water mains crossing or close to your development. Thames Water do NOT permit the building over or construction within 3m of water mains. If you're planning significant works near our mains (within 3m) we'll need to check that your development doesn't reduce capacity, limit repair or maintenance activities during and after construction, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes.

<https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fdevelopers%2Flarger-scale-developments%2Fplanning-your-development%2Fworking-near-our-pipes&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7Ce48155fc10374b112e7208dd5ff5c1c6%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638772231328029325%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiIwLjAuMDAwMCIsIlAiOiJXaW4zMilskFOIjoITWFpbGlldUIjoyfQ%3D%3D%7C0%7C%7C%7C&sdata=p4RTxDhvGdbqBsdhVYrQZEtTSET0%2FUIMLa%2F97HtKfo0%3D&reserved=0>

Yours faithfully

Development Planning Department

Development Planning,

Thames Water,

Maple Lodge STW,

Denham Way,

Rickmansworth,

WD3 9SQ

[Tel:020 3577 9998](tel:02035779998)

Email: devcon.team@thameswater.co.uk