





- Drawing for Planning purpose only, DO NOT construct from drawing. Please refer to engineer for detailed specification.
- All Free standing walls should be compliant with the code of practice for the use of masonry. Structural use of unreinforced masonry: BS 5628-1:2005.
- All pedestrians & guard rail installation and production must be compliant with BS 3049:1976.
- Refer to Boundary Treatment plan for location of walls.
- All build ups to be specified and detailed as per Engineers recommendation.

Key

- A. Variable height 1200mm/1800mm high brick wall.** 215 x 102.5 x 65mm brick sizing with 10mm mortar joints - exact brick to match architectural specification or similar approved
- B. Brick coping** - 215 x 65 x 102.5mm brick to match architectural specification.
- C. Construction build up and sub layers to be provided as per Engineers detail and specification.**

REV	NOTES	DATE
	Nine Mile Ride, Finchampstead	-
	Typical 1800mm Brick Wall	DH/DC
230122A D 03 03	1:20 @ A3	MAR 25

CliftonEmerydesign

Hems House, 84 Longbrook Street, Exeter, Devon, EX4 6AP
T: 01392 368866 W: www.cliftonemerydesign.co.uk M: mail@cliftonemerydesign.co.uk

DRAWING—STATUS Planning

CONTRACTORS MUST CHECK ALL DIMENSIONS ON SITE. ONLY FIGURED DIMENSIONS ARE TO BE WORKED FROM. THIS DRAWING IS COPYRIGHT.