

Date: 16 May 2025
Application: 251160



**WOKINGHAM
BOROUGH COUNCIL**

WBC Highways

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Highways,

Discharge of condition Consultation

Application Number: 251160

Applicant: Mr Jon Furneaux

Site Address: Land At Rear Of, 6 Johnson Drive, Finchampstead, Wokingham, RG40 3NW

Parish: Finchampstead

Grid Reference: Easting - 480593, Northing - 165183

Type of Development:

Proposal: Application for submission of details to comply with the following conditions of planning consent 233086 dated 09/05/25. Condition 3 relates to ground and building levels; 6 to highway construction details; 7 to access construction; 9 to cycle parking; 11 to a Construction Environmental Management Plan (Biodiversity); 12 to ecological enhancement; 13 to biodiversity gain; 14 to a Habitat Creation Management and Monitoring Plan; 15 to landscape proposals; 16 to a Landscape and Ecological Management Plan; 17 to protection of trees; 19 to a Sustainable Urban Drainage System; 20 to archaeology, and 23 to accessibility.

Case Officer: Andrew Chugg

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 251160. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	JP		
Service	WBC Highways	App No:	251160
Address:	Land At Rear Of, 6 Johnson Drive, Finchampstead, Wokingham, RG40 3NW.		
Proposal:	Application for submission of details to comply with the following conditions of planning consent 233086 dated 09/05/25. Condition 3 relates to ground and building levels; 6 to highway construction details; 7 to access construction; 9 to cycle parking; 11 to a Construction Environmental Management Plan (Biodiversity); 12 to ecological enhancement; 13 to biodiversity gain; 14 to a Habitat Creation Management and Monitoring Plan; 15 to landscape proposals; 16 to a Landscape and Ecological Management Plan; 17 to protection of trees; 19 to a Sustainable Urban Drainage System; 20 to archaeology, and 23 to accessibility.		
Type of Development:			
Site Visit Made:	Yes/No		

Summary Of Recommendations

- ☐ No comment
- ☐ No objection
- ☐ No objection subject to conditions (and reasons) **stated below**
- ☒ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

General

The proposal seeks consents for discharging conditions 3, 6, 7, 9, 11, 12, 13, 14, 15, 16, 17, 19, 20 and 23 for Planning Application Reference 233086 for one dwelling house. This memo responds on the submissions related to highway grounds.

Application for technical acceptance is required for discharging Conditions 3, 6, 7 and 15. Once technical acceptance has been granted by the Highways Agreement team, highways will then and only then be able to recommend discharge of this condition.

Condition 9 – Cycle Parking

According to the WBC parking standards, three cycle parking allocation is required for dwelling with 6+ habitable rooms.

While the positions of the cycle sheds and direct accesses to the rear gardens have been indicated on the hard landscaping plan, the Highways would have expected to review the elevations and internal dimensions of cycle parking to ensure the proposed sheds are of suitable dimensions.

Conditions & Reasons (if required)			
Date:	20/5/2025	Signed:	JP