

3rd Party Planning Application – 242421

Wokingham District Council

Our DTS Ref: 77848

P.O Box 157

Your Ref: 242421

Shute End

WOKINGHAM

Berks

RG40 1WR

10 October 2024

Dear Sir/Madam

Re: SCHOOL ROAD, ARBORFIELD CROSS, WORKINGHAM, READING, RG2 9NX

Waste Comments

Thames Water would advise that with regard to FOUL WATER sewerage network infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

The application indicates that SURFACE WATER will NOT be discharged to the public network and as such Thames Water has no objection, however approval should be sought from the Lead Local Flood Authority. Should the applicant subsequently seek a connection to discharge surface water into the public network in the future then we would consider this to be a material change to the proposal, which would require an amendment to the application at which point we would need to review our position.

There are public sewers crossing or close to your development. If you're planning significant work near our sewers, it's important that you minimize the risk of damage. We'll need to check that your development doesn't limit repair or maintenance activities, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes.

<https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fdevelopers%2Flarger-scale-developments%2Fplanning-your-development%2Fworking-near-our->

[pipes&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7Cc0fa3f2d10b748449de608dc
e92acb69%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638641617234976228%7CUnkn
own%7CTWFpbGZsb3d8eyJWljojMC4wLjAwMDAiLCJQIjoiV2luMzliLCJBTiI6Ikl1haWwiLCJXVCI6Mn0%3
D%7C0%7C%7C%7C&sdata=U%2Bwm%2F3%2F0emu521r2txweA5sjcKQsDbfnyLWjq0ZS3rw%3D&res
erved=0](https://www.thameswater.co.uk/development-services/working-near-our-pipes)

Water Comments

The proposed development is located within 5m of a strategic water main. Thames Water do NOT permit the building over or construction within 5m, of strategic water mains. Thames Water request that the following condition be added to any planning permission. No construction shall take place within 5m of the water main. Information detailing how the developer intends to divert the asset / align the development, so as to prevent the potential for damage to subsurface potable water infrastructure, must be submitted to and approved in writing by the local planning authority in consultation with Thames Water. Any construction must be undertaken in accordance with the terms of the approved information. Unrestricted access must be available at all times for the maintenance and repair of the asset during and after the construction works. Reason: The proposed works will be in close proximity to underground strategic water main, utility infrastructure. The works has the potential to impact on local underground water utility infrastructure. Please read our guide 'working near our assets' to ensure your workings will be in line with the necessary processes you need to follow if you're considering working above or near our pipes or other structures.

[https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fdevelopers%2Flarger-scale-developments%2Fplanning-your-development%2Fworking-near-our-pipes&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7Cc0fa3f2d10b748449de608dc
e92acb69%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638641617235010269%7CUnkn
own%7CTWFpbGZsb3d8eyJWljojMC4wLjAwMDAiLCJQIjoiV2luMzliLCJBTiI6Ikl1haWwiLCJXVCI6Mn0%3
D%7C0%7C%7C%7C&sdata=1cg%2FD9%2F4fekhYRF6%2B00tloQ4qaLI8whBzfA2dyjQdg8%3D&reserved=0](https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fdevelopers%2Flarger-scale-developments%2Fplanning-your-development%2Fworking-near-our-pipes&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7Cc0fa3f2d10b748449de608dc
e92acb69%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638641617235010269%7CUnkn
own%7CTWFpbGZsb3d8eyJWljojMC4wLjAwMDAiLCJQIjoiV2luMzliLCJBTiI6Ikl1haWwiLCJXVCI6Mn0%3
D%7C0%7C%7C%7C&sdata=1cg%2FD9%2F4fekhYRF6%2B00tloQ4qaLI8whBzfA2dyjQdg8%3D&reserved=0) Should you require further information please contact Thames Water. Email: developer.services@thameswater.co.uk.

Following initial investigations, Thames Water has identified an inability of the existing water network infrastructure to accommodate the needs of this development proposal. As such Thames Water request that the following condition be added to any planning permission. No development shall be occupied until confirmation has been provided that either:- all water network upgrades required to accommodate the additional demand to serve the development have been completed; or - a development and infrastructure phasing plan has been agreed with Thames Water to allow development to be occupied. Where a development and infrastructure phasing plan is agreed no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan. Reason - The development may lead to no / low water pressure and network reinforcement works are anticipated to be necessary to ensure that sufficient capacity is made available to accommodate additional demand anticipated from the new development" The

developer can request information to support the discharge of this condition by visiting the Thames Water website at thameswater.co.uk/preplanning. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (e-mail: devcon.team@thameswater.co.uk) prior to the planning application approval.

Yours faithfully

Development Planning Department

Development Planning,

Thames Water,

Maple Lodge STW,

Denham Way,

Rickmansworth,

WD3 9SQ

[Tel:020 3577 9998](tel:02035779998)

Email: devcon.team@thameswater.co.uk