

Raymond Barclay - 3, Adams Way, Earley, RG6 5UT

MCS 020(a) - Manual Sound Calculator

Assessment Details

Heat pump model is Cosy9 and it is 5.5 metres from the assessment window. There are 3 Reflecting Surfaces including the floor and it is Fully seen.

The assessment position is one metre perpendicular to the centre of the closest habitable room.

Step	Instructions		MCS contractor results/notes
1	Assesment date		26/09/2025
2	Assessment position	Assessment windows of No2 Adams Way, first floor, front elevation, looking north east	
			
3	A-weighted sound power level of the heat pump dB(A)		57
4a	Determine the directivity 'Q' of the heat pump noise.		Q8
4b	Measure the distance from the heat pump to the assessment position in metres		5.5
5	Determination of barrier correction - select barrier type		No barrier
6	Determination of barrier correction - select line of sight		Fully seen
7	Calculate Sound Pressure Level		40.2
8	Final Result?		Fail