

EASTERN
GATEWAY
APPROVED
UNDER
APPLICATION
NUMBER
192928



© ABLEY LETCHFORD PARTNERSHIP LTD.
This drawing should not be reproduced without
consent.

- DRAINAGE NOTES:
1. Do not scale.
 2. Refer to all other Project Drawings and supporting notes.
 3. All adoptable drainage works to be constructed as detailed in Design and Construction Guidance or as stipulated in the Water Authorities Addendum.
 4. All public sewers are to be the subject of a Section 104 agreement of the Water Industry Act 1991.
 5. Invert levels of existing manholes, and sewers are to be checked on site before construction commences and results reported to engineers.
 6. The Contractor is responsible for maintaining continuity of flow for all existing sewers within the site boundary and limit of works for the duration of the project.
 8. All drainage networks to comply with BS EN124, and be stamped with the Kitemark covers to suit loading as below:
 - Carriageway and Road: D400 (Supplier to be approved by WMC, otherwise 600 to be used)
 - Driveways and Verges: C250
 - Footways and Pedestrian Areas: B125
 - Gardens/Landscaping: A15
 9. All sewer pipes, up to, and including 600mm are to be verified class or PVC-U to BS EN252 and BS EN14014 respectively. All sewer pipes 675mm diameter and above to be concrete pipes to BS EN315.
 10. All drainage shall be installed and tested strictly in accordance with the Manufacturer's printed instructions, BS EN 752, BS EN 12051, Local Water Authority requirements and the Building Regulations.
 11. All building shall be Class 5 unless noted otherwise.
 12. All trenches under existing and proposed public highways are to be backfilled with thoroughly compacted Type 2 granular sub-base material.
 13. Drainage laid beneath roads and areas of vehicular access (car parking etc) with less than 1200mm of cover shall be encased in concrete and surrounded with associated movement joints. Drainage laid beneath paths, footways and pedestrian areas with less than 900mm of cover shall be similarly treated.
 14. Chambers with outgoing pipes greater than 600mm diameter shall be fitted with guard bars, safety chairs or other approved safety devices.
 15. The use of precast concrete products made with sulphate resisting cement is mandatory, unless a laboratory report proves such products are not necessary.
 16. All gully connections to use a minimum diameter pipe of 150mm and to be surrounded by a minimum of 150mm of grade C45/20 concrete over its full length which should not exceed 15m and its connection to the carrier system.
 17. All sewers to be abandoned must be surveyed to identify any lateral connections that are still live with any found to be reported to the Engineer.
 18. All foul and storm water drains which are not to be adopted as public sewers shall be in accordance with Document H of the Building Regulations, together with NHBC Standards Chapter 5 and BS8001.
 19. Where pipes pass through footings, retaining or screen walls, limits to be provided over drains.
 20. Where inverts are less than 0.6m deep inspection chambers (min dia. 100mm) or access fittings (125 x 100mm) to be used, elsewhere proprietary plastic, brick or pcc to be used and used in accordance with Table 11 of Document H of the Building Regulations (0.6m to invert min DN300, 0.6m to invert min DN475).
 21. All gullies connected direct to drains to be adopted.
 22. Adequate precautions in accordance with Approved Document H and manufacturer's recommendations to be taken to protect drains (particularly plastic) at shallow depths.
 23. Trees and shrubs of a large size or heavy canopy with a moderate or high water demand must not be planted within any sewer easement.
 24. Gullies within and adjacent to area of site works to be suction drained at commencement and completion of works.
 25. 1m deep root barrier of an approved type to be installed vertically along the back edging kerb of all areas of footway demarcation to protect from both proposed and future plantation.

- DRAINAGE KEY (1:500)
- STORM**
- Proposed adoptable sewer & M1
 - Highway gully and 150mmØ connection
 - Brickwork headwall refer to A389-LRDD-512 for detail
 - Proposed Basin/Sewals
 - Proposed Rain Garden Tree Pit and Outfall refer to A389-LRDD-512 for detail
 - Proposed Beamy Block Kerb and Outfall or similar approved
 - Proposed ACO 105 Kerbs and Outfall or similar approved
- FOUL**
- Proposed Sewer (not for adoption)
 - Proposed Manhole (not for adoption)
- Gully Catchments**
- Proposed Rain Garden Tree Pit Catchments
 - Proposed ACO or Beamy Kerb Catchment

0 10 20 30m		Scale 1:500	
C02	06.25	FOR SECTION 73 APPROVAL	RIS
C01	06.25	CONSTRUCTION ISSUE FOLLOWING TECHNICAL APPROVAL BY WMC	RIS
Rev	Date	Description	Drawn

Abley Letchford
www.ableyletchford.co.uk

Client
**MILLER HOMES
KIER VENTURES
KINGACRE ESTATES LTD.**

Project
**SOUTH WOKINGHAM SDL
R10-R14 LINK ROAD
DETAILED DESIGN**

Title
GULLY CATCHMENT PLAN

Status
FOR CONSTRUCTION

Scale	Date	Drawn	Checked
1:500 @ A0	MAY 2025	RG	RF
Drawn by	Revised		
A389-LRDD-505		C02	