

Date: 16 April 2025
Application: 250923



WOKINGHAM
BOROUGH COUNCIL

WBC Highways

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Highways,

Householder Consultation

Application Number: 250923

Applicant: Mr Mansoor Qureshi

Site Address: 59 Woodlands Avenue, Woodley, Wokingham, RG5 3HF

Parish: Woodley

Grid Reference: Easting - 475716, Northing - 173072

Type of Development: Other Householder

Proposal: Householder application for the proposed erection of a single storey rear extension following part demolition of existing living/dining room and chimney, plus conversion of the loft, including the insertion of 2no. dormers to create first floor habitable accommodation.

Case Officer: Cameron Young

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 250923. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	JP		
Service	WBC Highways	App No:	250923
Address:	59 Woodlands Avenue, Woodley, Wokingham, RG5 3HF.		
Proposal:	Householder application for the proposed erection of a single storey rear extension following part demolition of existing living/dining room and chimney, plus conversion of the loft, including the insertion of 2no. dormers to create first floor habitable accommodation.		
Type of Development:	Other Householder		
Site Visit Made:	Yes/No		

Summary Of Recommendations

- ☐ No comment
- ☒ No objection
- ☐ No objection subject to conditions (and reasons) **stated below**
- ☐ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

The proposal increases the numbers of habitable rooms from 4 to 7. Three existing driveway parking will be retained.

According to the WBC Car Parking Standards, the development of such scale in Urban location will require three parking within the red line boundary. Each parking space shall have minimum dimensions of 5.0m x 2.5m.

The retained driveway parking spaces are sufficient to meet the council's requirement, which is acceptable.

No negative impacts on abilities for cycle storage are expected, which is acceptable.

Conditions & Reasons (if required)

Date:	22/4/2025	Signed:	JP
--------------	-----------	----------------	----