

Date: 9 April 2025
Application: 250684



**WOKINGHAM
BOROUGH COUNCIL**

WBC Highways

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Highways,

Householder Consultation

Application Number: 250684

Applicant: Mr Sorin Irinel Kosferenc

Site Address: 23 Heathermount Drive, Crowthorne, Wokingham, RG45 6HJ

Parish: Wokingham Without

Grid Reference: Easting - 482991, Northing - 164606

Type of Development: Other Householder

Proposal: Householder application for the proposed erection of a two storey rear extension along with changes to fenestration plus rear chimney removal.

Case Officer: Cameron Young

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 250684. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	JP		
Service	WBC Highways	App No:	250684
Address:	23 Heathermount Drive, Crowthorne, Wokingham, RG45 6HJ.		
Proposal:	Householder application for the proposed erection of a two storey rear extension along with changes to fenestration plus rear chimney removal.		
Type of Development:	Other Householder		
Site Visit Made:	Yes/No		

Summary Of Recommendations

- ☐ No comment
☒ No objection
☐ No objection subject to conditions (and reasons) **stated below**
☐ Request further information before determination as **stated below**
☐ Objection due to the reason(s) **stated below**

Comments On Proposal

The proposal will increase the numbers of habitable rooms from 5 to 6. As the existing and proposed garage do not fully meet the council's requirement for car parking, there will be no gain or loss of parking space. Two driveway parking will be retained.

According to the WBC Car Parking Standards, the development of such scale in Urban location will require two parking within the red line boundary. Each parking space shall have minimum dimensions of 5.0m x 2.5m.

The retainment of existing parking meets the council's parking requirement, which is acceptable.

No negative impacts on abilities for cycle storage are expected, which is acceptable.

Conditions & Reasons (if required)

Date:	10/4/2025	Signed:	JP
--------------	-----------	----------------	----