

3rd Party Planning Application – 250735

Wokingham District Council

Our DTS Ref: 77848

P.O Box 157

Your Ref: 250735

Shute End

WOKINGHAM

Berks

RG40 1WR

14 April 2025

Dear Sir/Madam

Re: SCHOOL ROAD, ARBORFIELD CROSS, WORKINGHAM, READING, RG2 9NX

Waste Comments

The application indicates that SURFACE WATER will NOT be discharged to the public network and as such Thames Water has no objection, however approval should be sought from the Lead Local Flood Authority. Should the applicant subsequently seek a connection to discharge surface water into the public network in the future then we would consider this to be a material change to the proposal, which would require an amendment to the application at which point we would need to review our position.

There are public sewers crossing or close to your development. If you're planning significant work near our sewers, it's important that you minimize the risk of damage. We'll need to check that your development doesn't limit repair or maintenance activities, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes.

<https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fdevelopers%2Flarger-scale-developments%2Fplanning-your-development%2Fworking-near-our-pipes&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7C0a3aaec060ce47666ee208dd7b47c3a0%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638802270348139774%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiIwLjAuMDAwMCIsIlAiOiJXaW4zMilslkFOljoitWFBpbCIsIlIdUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=J2PTk7iwChK%2FyxM7h3NwYkOz5AxJ%2F5ZPsQYnONPgOm8%3D&reserved=0>

Thames Water would advise that with regard to FOUL WATER sewerage network infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

Following initial investigations, Thames Water has identified an inability of the existing SEWAGE TREATMENT WORKS infrastructure to accommodate the needs of this development proposal. As such Thames Water request the following condition be added to any planning permission. “No development shall be occupied until confirmation has been provided that either:- all sewage works upgrades required to accommodate the additional flows from the development have been completed; or - a development and infrastructure phasing plan has been agreed with the Local Authority in consultation with Thames Water to allow development to be occupied. Where a development and infrastructure phasing plan is agreed no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan. Reason – Sewage Treatment Upgrades are likely to be required to accommodate the proposed development. Any upgrade works identified will be necessary in order to avoid sewage flooding and/or potential pollution incidents.” The developer can request information to support the discharge of this condition by visiting the Thames Water website at Development Planning Department (telephone 0203 577 9998) prior to the planning application approval. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (e-mail: devcon.team@thameswater.co.uk) prior to the planning application approval.

Water Comments

There are water mains crossing or close to your development. Thames Water do NOT permit the building over or construction within 3m of water mains. If you're planning significant works near our mains (within 3m) we'll need to check that your development doesn't reduce capacity, limit repair or maintenance activities during and after construction, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes.

<https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fdevelopers%2Flarger-scale-developments%2Fplanning-your-development%2Fworking-near-our-pipes&data=05%7C02%7Cplanning.enquiries%40wokingham.gov.uk%7C0a3aaec060ce47666ee208dd7b47c3a0%7C996ee15c0b3e4a6f8e65120a9a51821a%7C0%7C0%7C638802270348170371%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiJlZlJlYiAuMDAwMCIsIlAiOiJXaW4zMilslkFOljoitWFlpbGlldiUjoyfQ%3D%3D%7C0%7C%7C%7C&sdata=0fQjOniLjqNlgD2%2BVCWBRF9k2y6EkCAeAjuawLePM0Q%3D&reserved=0>

If you are planning on using mains water for construction purposes, it's important you let Thames Water know before you start using it, to avoid potential fines for improper usage. More information and how to apply can be found online at thameswater.co.uk/buildingwater.

Following initial investigations, Thames Water has identified an inability of the existing water network infrastructure to accommodate the needs of this development proposal. As such Thames Water request that the following condition be added to any planning permission. No development shall be occupied until confirmation has been provided that either:- all water network upgrades required to accommodate the additional demand to serve the development have been completed; or - a development and infrastructure phasing plan has been agreed with Thames Water to allow development to be occupied. Where a development and infrastructure phasing plan is agreed no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan. Reason - The development may lead to no / low water pressure and network reinforcement works are anticipated to be necessary to ensure that sufficient capacity is made available to accommodate additional demand anticipated from the new development” The developer can request information to support the discharge of this condition by visiting the Thames Water website at thameswater.co.uk/preplanning. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (e-mail: devcon.team@thameswater.co.uk) prior to the planning application approval.

Supplementary Comments

An upgrade is planned for Arborfield STW. This will improve its ability to treat the volumes of incoming sewage, reducing the need for untreated discharges in wet weather. The scheme is due to complete in 2028.

Yours faithfully

Development Planning Department

Development Planning,

Thames Water,

Maple Lodge STW,

Denham Way,

Rickmansworth,

WD3 9SQ

[Tel:020 3577 9998](tel:02035779998)

Email: devcon.team@thameswater.co.uk