

Structural Feasibility Report

Main House

New Roof

Consulting Structural & Civil Engineers

Maidenhead Office:

Regus, Concorde Park, Concorde Road, Maidenhead, Berkshire, SL6 4BY

Phone : 07471 406 609

Email : mudassar70@yahoo.com



VECTOR STRUCTURES LIMITED
Bringing Ideas to Life

Client: Mr Zubair Hussain

Address: L'Ortolan, Church Lane, Shinfield,
Reading RG2 9BY

Report Prepared by: Mudassar Khokhar – Structural Engineer
BEng. MSc. CEng PEng MICE

Document Ref: 2025.Lortolan.RP.S.0300-A1.C1
Date: 03/12/2025

Document Control Sheet

This document has been issued and amended as follows:

| Issue Date | Issue | Prepared by | Comments |
|------------|-------|--------------------------------------|-----------------------|
| 16/03/2025 | C1 | M Khokhar, BEng. MSc. CEng PEng MICE | 1 st Issue |
| 22/05/2025 | C2 | M Khokhar, BEng. MSc. CEng PEng MICE | 2 nd Issue |
| 24/07/2025 | C3 | M Khokhar, BEng. MSc. CEng PEng MICE | 3 rd Issue |
| 01/09/2025 | C4 | M Khokhar, BEng. MSc. CEng PEng MICE | 4 th Issue |
| 03/12/2025 | C5 | M Khokhar, BEng. MSc. CEng PEng MICE | 5 th Issue |

Note: 5th Issue covers the main house elements only

Disclaimer

This report has been prepared with all reasonable skill, care, and diligence in accordance with the instructions of the client. The report is for the sole use of the above-named client, and the author shall not be held liable for any use of the report and its content for any purpose other than that for which it was prepared or provided to the Client.

No part of this document may be copied or reproduced without the prior written approval of the author.

TABLE OF CONTENTS

| | | |
|-----|--------------------------------|---|
| 1 | INTRODUCTION..... | 4 |
| 1.1 | Background..... | 4 |
| 1.2 | Scope of Works..... | 5 |
| 2 | FEASIBILITY ASPECTS..... | 6 |
| 2.1 | Main Building – New Roof | 6 |

1 INTRODUCTION

L'Ortolan is a Grade II listed former Vicarage built in circa 1840, in the style of the Gothic revival with brick elevations and stone mullions. The building has been used as a restaurant since 1978 and is to be converted to residential use to become a delightful family home in a village setting that has excellent transport links. Set within established grounds with ample parking, the property stands in well-maintained grounds on a total plot of 0.92 acre and lawned grounds extend to the front and to the western boundary with a number of mature trees. The property owner has already obtained relevant planning permission and/or listed building consent for change of use. The 5-bed main building is set over two floors with a cellar. The property also has an additional detached building located to the rear (cottage/annex); currently this is used as an office.

This report covers the feasibility study on structural aspects of the new roof in main house.

1.1 Background

- 1.1.1 Vector Structures Limited were commissioned by Mr Zubair Hussain to look into feasibility study of the existing property at L'Ortolan, Church Lane, Shinfield, Reading RG2 9BY.
- 1.1.2 The report will look into the structural aspects and challenges related to new roof of the main house. Reference is made to previously submitted architectural drawings.
- 1.1.3 The comments in this report are based on the visual inspection.
- 1.1.4 A trial hole was dug to check the state and depth of existing foundations at the front corner of the main house. Relevant details, including key dimensions, are covered in this report.

1.2 Scope of Works



- 1.2.1 The purpose of this feasibility study is to look into the possibility of having a new roof in the main house.
- 1.2.2 This report lists the areas where further structural investigations have been completed.

2 FEASIBILITY ASPECTS OF PROPOSED ADDITIONS

2.1 Main Building New Roof



Photo 1 – Existing Main House – Front View- Flat Roof.



Photo 2 – Main House – Front View - Proposed New Roof.



Photo 3 – Main House – Rear View - Proposed New Roof.






Photo 4a and 4b – Main House Plan – New Roof - Indicative /concept structural member framing at loft and roof level.

The new roof of the main house will be in timber to keep dead weight of the roof on existing structure to minimum. Where required, steel beams and steel posts will be introduced to support floor, bridge long spans and to provide support and stability to new roof rafters. Braced bays will be introduced to guard against wind forces that may act on the new roof. Existing roof members will be exposed, measured and checked with latest codes against structural performance capacity. It is worth noting that there will be a change in use due to proposed works; therefore, all existing roof members will be checked against floor /occupancy load of 1.5kN/m² (Live Load).

A topographical survey was carried out a few months ago and architectural drawings were developed from the information provided. However, for structural checks, intrusive investigations will be required to ascertain the following elements that are not covered in the topo. Some of these checks have already been carried out and described below.

- There are no timber sections in existing roof. The roof is made up of concrete sections that will be exposed during construction.
- Thickness of any load bearing walls and wall material are available from topo survey.
- Presence of any other hidden structural members and existing services will be checked during construction or pre-construction phase.
- Main house existing foundations were checked. Trial pit dug in May 2025 at the front corner of main house has shown that the existing concrete foundation is minimum 600mm thick and founded at approx. 450-500 mm below existing ground level. The approximate plan projection of this footing is approximately 1000mm from outer face of existing brick wall. During initial planning stages, this seems satisfactory; further checks will be performed before the final building control drawings are produced.



Photo 4a: Main House Foundation Trial Pit

Key points are as follows.

- All sloping roof rafters at higher level of main roof will be in timber (shown in red).
- All flat roof rafters at higher level of main roof will be in timber (shown in cyan). These will support weight of new solar panels.
- Steel framing may be used at selected location. These members will support roof timber framing (shown in yellow)
- All flat roof rafters in lower level of main roof will be in timber (shown in green). These will span onto steel beams (shown in dotted black)
- All timber roof rafters at both roof positions (higher and lower-level roof) will be doubled up at all opening positions, around chimneys, around skylight openings and any other floor openings.
- For stability, all timber wall plates will be strapped down to walls. Stability against wind /lateral forces will be achieved by introducing braced bays (shown in dotted yellow lines)
- The floor framing will consist of use of light weight timber and use of selected steel beams. These aspects will be considered at preliminary structural design stage when the type, size, weight and supplier of roof lights, solar panels etc. are known and after appropriate planning permission has been granted.

I would like to point out that there was an additional floor when the main house was first built (photo below). It was removed during subsequent renovations. Given that the property was previously designed for extra floor, addition of a new floor at this stage is deemed to be acceptable.



Every effort will be made to keep the historic character of the main house maintained by use of appropriate structural elements.

Conclusion

The structural proposals listed above for main house are workable, value engineered keeping in mind the historic nature of the property. The current structure of the building, including structural walls on strong foundations is capable of taking load from proposed light weight structural steel framing and additions without having to make any significant changes to the existing structure; hence the original character of the historic building is not compromised.