

Date: 15 August 2025
Application: 251965



WOKINGHAM
BOROUGH COUNCIL

WBC Highways

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear WBC Highways,

Householder Consultation

Application Number: 251965

Applicant: Mr and Mrs Tyler

Site Address: 2 Ardwell Close, Crowthorne, Wokingham, RG45 6BA

Parish: Invalid code

Grid Reference: Easting - 482319, Northing - 164007

Type of Development: Other Householder

Proposal: Householder application for the proposed single storey rear extension, and part two storey side extension with 2 no. roof light windows, proposed front entrance porch, internal alterations and changes to the fenestration including replacing the existing flat roof to the previous two storey rear extension with a pitched roof.

Case Officer: Tariq Bailey-Biggs

Development Management has received the above application and we require your comments on the proposal using the recommended memorandum below. The documents associated with this are available to view in NEC DM using the application number 251965. Alternatively, public documents are available to view on the Council's planning application search page: [Wokingham Borough Council Online Planning](#).

Please index your response into NEC DM against the application. If you are recommending conditions, you should give a reason with reference to relevant policies. A list of standard conditions can be found on the Z Drive at: [Z:\Standard Planning Conditions](#).

Your observations are required in respect of this application within **10 working days** of the above date or **15 working days** if the development type is classed as a major development.

Yours sincerely,
Development Management & Compliance

MEMORANDUM

From:	JP		
Service	WBC Highways	App No:	251965
Address:	2 Ardwell Close, Crowthorne, Wokingham, RG45 6BA.		
Proposal:	Householder application for the proposed single storey rear extension, and part two storey side extension with 2 no. roof light windows, proposed front entrance porch, internal alterations and changes to the fenestration including replacing the existing flat roof to the previous two storey rear extension with a pitched roof.		
Type of Development:	Other Householder		
Site Visit Made:	Yes/No		

Summary Of Recommendations

- ☐ No comment
- ☒ No objection
- ☐ No objection subject to conditions (and reasons) **stated below**
- ☐ Request further information before determination as **stated below**
- ☐ Objection due to the reason(s) **stated below**

Comments On Proposal

The applicant proposes to increase the numbers of habitable rooms from 7 to 8. Four driveway parking are proposed within the red line.

According to the WBC Car Parking Standards, the development of such scale in Urban location will require three parking within the red line boundary. Each parking space shall have minimum dimensions of 5.0m x 2.5m.

The proposed driveway can accommodate the required parking provisions within the red line, which is acceptable.

No negative impacts on abilities for cycle storage are expected, which is acceptable.

Conditions & Reasons (if required)

Date:	18/8/2025	Signed:	JP
--------------	-----------	----------------	----