

Date: 11 March 2026
Application: 260282



**WOKINGHAM
BOROUGH COUNCIL**

Mr Mustafa Chaudhary
Space Office Limited
104 Westfield Road
Caversham
Reading
RG4 8HJ

Development Management &
Compliance

P.O. Box 157

Shute End, Wokingham

Berkshire, RG40 1BN

Tel: (0118) 974 6000

Minicom No: (0118) 974 6991

Dear Mr Mustafa Chaudhary,

HOUSEHOLDER PRIOR APPROVAL DECISION

Application Number: 260282

Site Address: 27 Moor Copse Close, Earley, Wokingham, RG6 7NA

Proposal: Application for the prior approval of the erection of a single storey rear extension, which would extend beyond the rear wall of the original house by 6.00m, for which the maximum height would be 4.00m and the height of the eaves 3.00m.

Town and Country Planning (General Permitted Development) (England) Order 2015. Process set out by Condition A.4 of Class A of Part 1 of Schedule 2 of Article 3

I refer to your recent application registered on 3 February 2026 for determination as to whether prior approval is required for the erection of a single storey extension to the rear of the above dwelling.

I can confirm neighbour objections were received and the Council has therefore considered the details submitted and hereby confirms that prior approval is given. Please be aware that you will need to comply with Building Regulations in the construction of the development.

This written notice indicates that the proposed development would comply with paragraph A1. (g) of Schedule 2 Part 1 Class A of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended). It is important to note that this written notice does not indicate whether or not the proposed development would comply with any other of the limitations or conditions of Schedule 2 Part 1 Class A. If you require confirmation that the development would be lawful (i.e. that it would comply with all the limitations and conditions set out in Schedule 2 Part 1 Class A), then you can submit an application to the local planning authority for a Certificate of Lawful Development. For your information, building over a gas main or service that is located within your site could cause damage to pipework or potential gas leaks within buildings. You should check for information

relating to services within your site at [Home - LineSearchbeforeUdig \(lsbud.co.uk\)](http://Home-LineSearchbeforeUdig.lsbud.co.uk) and contact the Plant Protection Team at SGN on 0800 912 1722 or plantlocation@sgn.co.uk. The development stated above may be liable to pay the Community Infrastructure Levy. You must therefore complete and return a [form 5 notice of chargeable development.pdf \(planningportal.co.uk\)](http://form5noticeofchargeabledevelopment.pdf.planningportal.co.uk) prior to commencing to determine whether the development is liable. Failure to complete this form can incur a penalty surcharge. Please submit all CIL forms and enquiries to developer.contributions@wokingham.gov.uk.

Informatives

1. Whilst it would appear from the application that the proposed development is to be entirely within the curtilage of the application site, the granting of planning permission does not authorise you to gain access or carry out any works on, over or under your neighbour's land or property without first obtaining their consent, and does not obviate the need for compliance with the requirements of the Party Wall etc. Act 1996.

2. Where applicable, the approval above is subject to the following: The materials used in any exterior work (other than materials used in the construction of a conservatory) must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse.

Any upper-floor window located in a wall or roof slope forming a side elevation of the dwellinghouse must be obscure-glazed and non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.

Where the enlarged part of the dwellinghouse has more than a single storey, the roof pitch of the enlarged part must, so far as practicable, be the same as the roof pitch of the original dwellinghouse.

3. As no elevations have been submitted, this prior approval application does not give written confirmation that the development meets all of the limitations set out within Part 1, Class A of The Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended). The applicant is advised to check that the proposed elevations are in accordance with the general permitted development order before proceeding.

Yours sincerely,



Justin Turvey
Head of Development Management - Place & Growth
Date: 11/03/2026